

Dynamic modelling of CO₂ absorption for post combustion capture in coal-fired power plants

A. Lawal^a, M. Wang^{a,*}, P. Stephenson^b, H. Yeung^a

^a*Process Systems Engineering Group, School of Engineering, Cranfield University, Bedfordshire, MK43 0AL, UK.*

^b*RWE npower, Windmill Park, Swindon, SN5 6PB, UK.*

Abstract

Power generation from fossil fuel-fired power plants is the largest single source of CO₂ emissions. Post combustion capture via chemical absorption is viewed as the most mature CO₂ capture technique. This paper presents a study of the post-combustion CO₂ capture with monoethanolamine (MEA) based on dynamic modelling of the process. The aims of the project were to compare two different approaches (the equilibrium-based approach versus the rate-based approach) in modelling the absorber dynamically and to understand the dynamic behaviour of the absorber during part load operation and with disturbances from the stripper. A powerful modelling and simulation tool gPROMS was chosen to implement the proposed work. The study indicates that the rate-based model gives a better prediction of the chemical absorption process than the equilibrium-based model. The dynamic simulation of the absorber indicates normal absorber column operation could be maintained during part load operation by maintaining the ratio of the flow rates of the lean solvent and flue gas to the absorber. Disturbances in the CO₂ loading of the lean solvent to the absorber significantly affect absorber performance. Further work will extend the dynamic modelling to the stripper for whole plant analyses.

Keywords: CO₂ Capture, Chemical absorption, Dynamic modelling, Coal-fired power plant

1. Introduction

Power generation from fossil fuel-fired power plants is the largest single source of CO₂ emissions [1]. Coal-fired power plants release twice as much CO₂ per unit of electricity generated than natural gas power plants. However, these power plants play a vital role in meeting energy demands as coal is relatively cheap. In addition, coal-fired power plants can be operated flexibly as mid-merit plants in response to changes in supply and demand [2]. With growing concerns about the environmental impact of such plants effective CO₂ emission abatement strategies such as Carbon Capture and Storage (CCS) are required for their continued use. One approach to CCS is post combustion capture which involves the separation of CO₂ from the flue gas stream after combustion occurs (Figure 1). Chemical absorption is well suited for separating CO₂ from streams with low concentration of CO₂ (10-15% by volume) typical of pulverized fuel power plants [3,4].

1.1 Motivation

* Corresponding author. Tel.: +0044 1234 754655; Fax: +0044 1234 754685; Email address: meihong.wang@cranfield.ac.uk

Several studies have shown that the energy requirement for solvent regeneration would have adverse effects on power plant efficiency [5-8]. These effects have been studied using various steady state models and techno-economic assessments. However there are several gaps in the understanding of the impact of post combustion capture on the operability of the power plant. For instance, would such power plants be able to effectively operate at varying loads? What modifications would have to be made to the conventional start-up and shutdown procedures? What implications would heat integration between the power plant and CO₂ capture facility have on their operation [9]? These questions can be addressed by studying the dynamic behaviour of such plants. To achieve this, accurate dynamic models of the power plant and the CO₂ capture facility are required.

1.2. Post combustion capture via chemical absorption

Chemical absorption involves the reaction of CO₂ with a chemical solvent to form a weakly bonded intermediate compound which may be regenerated with the application of heat producing the original solvent and a CO₂ stream [3,4]. Monoethanolamine (MEA) being a primary amine reacts with CO₂ to produce carbamate via sets of liquid phase reactions [7,10]. A review of various reaction schemes describing this process is available in literature [11,12].

Figure 1 describes one of the popular technologies proposed for post combustion capture. The facility consists of two main units – the absorber and stripper columns which are both packed columns. Flue gas from the power plant is contacted counter-currently with lean MEA solution in the absorber. MEA chemically absorbs the CO₂ in the flue gas. This leaves a treated gas stream of much lower CO₂ content. The solvent solution (now Rich MEA) is regenerated in the stripper column using steam derived from the power generation process. CO₂ from the top of the column is compressed and transported away while the lean (regenerated) MEA solution is returned to the absorber column completing the cycle.

1.3 Novel contributions and outline of the paper

This study focuses on the dynamic model development of the absorber of the chemical absorption plant. It offers what is thought to be a unique comparison of the accuracy of two approaches to modelling the absorption process– the equilibrium-based and rate-based approaches. Also dynamic analyses of some disturbances to the absorber performance were carried out. Two disturbances were considered:

- Decreasing flue gas flow supplied to the absorber from the upstream power plant, and
- Increasing the CO₂ loading of the lean MEA solution from the stripper of the capture facility.

A review of various approaches to modelling the chemical absorption process is described in section 2. Two approaches were compared – the equilibrium and rate-based approaches. The model development process was described in section 3. These models were validated with results from a pilot plant study [13] in section 4. Two dynamic scenarios were simulated

59 – reducing power plant load and increasing CO₂ loading of the lean solvent. The results are presented in section 5.
60 Conclusions were drawn in section 6 and recommendations for future work were given in section 7.

61 **2. Developments in modelling chemical absorption of CO₂**

62 Post combustion capture with MEA is a reactive absorption process. Two main phenomena are involved: mass transfer of
63 CO₂ from the bulk vapour to the liquid solvent and the chemical reaction between CO₂ and the solvent.

64 A number of studies have employed steady state models of the chemical (or reactive) absorption process at different levels
65 of complexity. Kenig et al describes the different levels of complexity of these models as illustrated in Figure 2 [14].

66 The equilibrium stage models assume theoretical stages in which liquid and vapour phases attain equilibrium. These
67 models may assume the reactions are at equilibrium or may consider the reaction kinetics. The rate-based approach is more
68 appropriate in modelling reactive absorption processes since phase equilibrium is hardly attained in practice. At its lowest
69 level of complexity, the chemical reactions of the rate-based model are assumed to be at equilibrium. A more rigorous
70 approach involves the inclusion of an enhancement factor to estimate actual absorption rates (with chemical reactions)
71 from known physical absorption rates. The enhancement factor is calculated based on estimated reaction rates and is best
72 suited for processes involving single irreversible reactions. This approach has been employed by a number of authors in
73 developing steady state absorber and stripper models [15-17]. At the highest level available, reaction kinetics are modelled
74 directly. Models consider mass transfer resistances, electrolyte thermodynamics, the reaction system as well as the column
75 configurations and provide a direct estimation of concentration and temperature profiles by implementing reaction rates
76 directly into the transport and balance equations in the film and the bulk of the fluid. This approach has been applied to a
77 number of cases [10,14,18,19].

78 This study compares the equilibrium stage with the rate-based models both with reaction equilibrium (bottom and top left
79 models in Figure 2).

80 The dynamic behaviour of the CO₂ absorption process for post combustion capture using MEA has not been extensively
81 studied. Schneider et al considered the dynamic simulation of purification of coke plant gases [18]. Kvamsdal et al
82 considered the dynamic simulation of only the absorber of the process using dynamic models of reduced complexity. The
83 model employs an enhancement factor based on the assumption of pseudo first-order reaction regime. Kvamsdal et al
84 adjusted both inlet flue gas flow rates and absorber heights to match pilot plant performance. In this study only the inlet
85 flue gas flow rates to the absorber were adjusted. Kvamsdal et al also assumed a constant value for the heat of reaction and
86 vaporization of water [9].

87 **3. Model development**

88 This section describes the model development of the absorber using the equilibrium- and rate-based approaches.




89 3.1. Equilibrium-based approach

90 The equilibrium-based approach was implemented in Aspen Plus¹ based on its Radfrac column model. This model was
91 steady state and assumes theoretical stages in which liquid and vapour phases attain equilibrium and perfect mixing occurs.
92 To describe non-equilibrium processes, the performance of each stage is adjusted using an efficiency correction factor
93 [17,18]. For simulation purposes, the specifications presented in Table 1 were used. In section 4, all equilibrium based
94 results were obtained from Aspen Plus.

95 The physical property method used is the Electrolyte Non-random-two-liquid (NRTL) model with electrolyte inserts for
96 MEA. This insert includes new parameters and Henry's constant for CO₂ in MEA.

97 3.1.1. Aspen Properties MEA solution chemistry

98 MEA electrolyte solution chemistry is used to predict the equilibrium mass fractions in the liquid and vapour phases. The
99 following are the set of equilibrium reactions describing this chemistry [20]:



105 3.2. Rate-based approach

106 In the rate-based approach, actual rates of multi-component mass and heat transfer as well as chemical reactions are
107 considered directly [21]. The mass transfer is described using the two-film theory using the Maxwell Stefan formulation.
108 Heat and mass transfer resistances are modelled in the liquid and vapour films.

109 The rate-based model was developed from the Gas-Liquid Contactor model in Process Systems Enterprise's Advanced
110 Model Library using their process modelling tool, gPROMS. With gPROMS, accurate dynamic models of processes can be
111 developed as it is equation-based and inherently dynamic.

112 3.2.1. Model assumptions

113 The following assumptions were used in developing this dynamic model:

- 114 • Plug flow regime
- 115 • Linear pressure drop along the column
- 116 • No accumulation in liquid and vapour films as well as bulk vapour

¹ Aspen Technology Inc.

- 117 • Phase equilibrium at interface between liquid and vapour films
- 118 • Negligible oxygen content in the flue gas
- 119 • Negligible solvent degradation
- 120 • Negligible heat loss to the surroundings
- 121 • Liquid phase reactions

122 3.2.2. Material and energy balances

123 Material and energy balances are carried out on the bulk liquid and vapour.

124 Bulk Liquid: $\frac{dM_i}{dt} = \frac{-1}{L \cdot A} \frac{\partial F_i^L}{\partial y} + N_i \cdot Sp \cdot MW_i \cdot \omega$ (6)

125 $\frac{\partial F_i^L}{\partial y} \Big|_{y=1} = 0$ (7)

126 Where,

127 $M_i = x_i \times M, \quad i = 1, \dots, n$ (8)

128 $\sum_{i=1}^n x_i = 1$ (9)

129 y is the axial position relative to the top of the absorber packing ranging from 0 (or top) to 1 (or bottom of the packing).

130 $\frac{dU}{dt} = \frac{-1}{L \cdot A} \frac{\partial F_H^L}{\partial y} + Sp \cdot \omega (H_{liq}^{cond} + H_{liq}^{conv} + H_{abs})$ (10)

131 $\frac{\partial T}{\partial y} \Big|_{y=1} = 0$ (11)

132 Where

133 $H_{abs} = N_{CO_2} \times h_{abs}$ (12)

134 The specific heat of absorption, h_{abs} (J/mol), is estimated as a function of temperature and CO₂ loading based on
 135 expressions in literature [22]. F_H^L is the liquid enthalpy flow rate (J/s).

136 Bulk Vapour: $0 = \frac{-1}{L \cdot A} \frac{\partial F_i^V}{\partial y} - N_i \cdot Sp \cdot MW_i \cdot \omega$ (13)

137 $\frac{\partial F_i^V}{\partial y} \Big|_{y=1} = 0$ (14)

138 $0 = \frac{-1}{L \cdot A} \frac{\partial F_H^V}{\partial y} + Sp \cdot \omega (H_{vap}^{cond} + H_{vap}^{conv})$ (15)

3.2.3. Mass transfer

Mass transfer was modelled with resistances in the liquid and vapour films. The diffusivity (χ) of CO₂ in the liquid phase was based on expressions provided by Vaidya et al [23]. The diffusivity (χ) of CO₂ and other components in the vapour phase was estimated using the Fuller's equation [24]. Mass transfer coefficients in the liquid and vapour films were determined by correlations given by Onda et al [25]. Molar fluxes (N_i) of each component were estimated using the Maxwell-Stefan formulation (applied to both liquid and vapour phases):

$$\frac{1}{\delta} \frac{\partial x_i^M}{\partial z} = \frac{1}{c_t} \sum_{k=1}^n \left(\frac{x_i^M N_k - x_k^M N_i}{\chi_{i,k}} \frac{\mu^R}{\mu} \frac{T}{298.15} \right) \quad (16)$$

Where, c_t is the total molar concentration in the phase, δ is the film thickness and x_i^M is the molar fraction.

3.2.4. Physical properties

The physical property estimation models were set up in Aspen Properties. Through the CAPE-OPEN Thermo interface, gPROMS can take advantage of Aspen Properties' extensive physical property database. The Electrolyte-NRTL properties method was selected. For simplicity, only four main components were considered – MEA, water, carbon dioxide and nitrogen (oxygen content was incorporated into the nitrogen composition). Aspen properties also includes electrolyte inserts for the Electrolyte-NRTL property method where electrolyte solution chemistry is accounted for [20]. The same physical property model was used in the equilibrium- based model was used here as well. MEA electrolyte solution chemistry is used to predict the equilibrium mass fractions in the liquid and vapour phases at the interface. The same set of equilibrium reactions described in equations (1-5) is used.

4. Model validation

The models developed were validated using data from the Separations Research Program at the University of Texas at Austin. The absorber column of the pilot plant is a packed column with a diameter of 0.427m and total height of 6.1m. This column consists of two 3.05m packed bed sections with a collector plate and redistributor between the beds [13]. Out of the 48 experimental cases carried out in the research program, two cases (Cases 32 and 47) were selected for steady state validation purposes. These two cases were selected because of their relatively high and low liquid to gas (L/G) ratios respectively.

Table 2 shows the process conditions for the lean MEA and flue gas streams to the absorber while Table 3 shows some absorber column and packing specifications.

Simulation results were validated using the temperature profile of the absorber column measured in the pilot plant [13]. In addition the measured CO₂ loading of the amine solvent taken at different positions was compared with values obtained from simulation.

168 4.1 Validation and comparison of equilibrium- and rate-based models

169 4.1.1. Case 47

170 This case involved a relatively low liquid to gas (L/G) ratio thus a lower CO₂ capture level.

171 Because of the reported inaccuracy in the flue gas flow measurement [9,13], its value was adjusted to match reported
172 capture levels as shown in Table 4. Both the equilibrium and rate-based models predicted lower rich solvent loading than
173 what was measured while the absorption levels are virtually the same as measured.

174 The temperature profile in the absorber was used to validate the two models as shown in Figure 4. The rate-based model
175 gives a slightly better prediction of the temperature profile. The equilibrium-based model predicts generally lower
176 temperatures than what was measured.

177 4.1.2. Case 32

178 This case involved a relatively high liquid to gas (L/G) ratio thus a high CO₂ capture level.

179 Both models showed poor prediction of the temperature profile in the absorber. However, with further reduction in the inlet
180 flue gas rate to 0.11kg/s, better predictions were observed as shown in Figure 6. However, this change implies higher CO₂
181 capture levels than what was measured in the pilot plant (Table 5).

182 These discrepancies (as seen in Table 6) may be due to the assumption that the reactions between CO₂ and MEA are at
183 equilibrium as calculated by the electrolyte solution chemistry. Kinetically controlled reactions may therefore provide
184 better predictions of the trend. The rate-based model still gives a better prediction of the absorber temperature profile
185 (Figure 6) compared to the equilibrium based model. The equilibrium-based model predicts higher temperatures than those
186 measured in the pilot plant study.

187 5. Dynamic analysis

188 These analyses consider the effect of disturbances on the performance of the absorber. Two scenarios are considered:

- 189 • Reducing power plant load – as a mid-merit power plant, power generation would not be continuously at base-
190 load level. In this scenario, a 50% reduction in power plant load occurs.
- 191 • Increasing lean MEA solution loading – with disturbances in the stripper column operation, such as reduced
192 reboiler duty, the CO₂ loading of the lean MEA supplied to the absorber may increase. This scenario involves a
193 10% increase in lean loading.

194 5.1 Reducing power plant load

195 In this scenario, the upstream power plant load was reduced from base-load (100%) to 50% load. It was assumed that the
196 flue gas flow rate decreases correspondingly and the changes in component composition are negligible. This scenario was
197 applied to Case 32. Two cases were considered:

- Case-A: Change of flue gas flow rate without changing liquid (solvent) flow rate
- Case-B: Change of flue gas flow rate with corresponding decrease in liquid solvent rate to maintain CO₂ capture level

The process was simulated with the base-load conditions (Case 32) for three minutes after which the above changes were implemented in ten minutes. Finally conditions were maintained for eight minutes.

The two cases are illustrated in Figures 7

5.1.1 Case-A

From Figure 8, the 100s curve represents the profile before dropping load. The other curves show a trend of increasing absorption levels with time. Since the flue gas flow rate is ramped down with time while the solvent flow rate is constant, an increase in L/G ratio occurs.

Figure 9 shows the change in the CO₂ absorption level as the flue gas leaves the absorber with the L/G ratio. CO₂ absorption levels increase almost linearly with L/G ratio up to ratios of about 8.0. Afterwards, the rate of increase reduces. There is also a significant change in the temperature profile in the absorber as seen in Figure 10. The location of the temperature bulge gradually shifts toward the bottom of the column. Temperature values generally reduce as less quantities of CO₂ are absorbed.

5.1.2 Case-B

By reducing the lean solvent feed rate correspondingly (by 50%), roughly the same capture level and temperature profile (Figures 11 and 12) could be maintained through the period of change. This suggests that the absorption process is more sensitive to the L/G (liquid solvent to flue gas) ratio than their actual flow rates. Since the amount of steam required for regeneration corresponds to the amount of lean MEA circulated, the energy requirement of the stripper could be correspondingly reduced.

5.2 Increasing lean MEA solution loading

This scenario was applied to Case 32 (process conditions in Table 2). Conditions were maintained for three minutes. Then the CO₂ loading of the lean solution was ramped up by 10% (from 0.279 to 0.3069) within three minutes. Finally, conditions were then maintained for 30 minutes to achieve steady state. This is illustrated in Figure 13.

With increased CO₂ loading of the lean MEA supplied to the absorber, the CO₂ absorption level (Figure 14) drops from 94.4% to 85.5%. CO₂ absorption levels could be maintained by either increasing the flow rate of lean MEA solvent to the absorber or decreasing the CO₂ loading of the solvent. The latter can be achieved by either increasing the stripper's reboiler duty or adding fresh MEA solution from solvent makeup tanks. Increasing the total solvent flow rate by 10% only results

227 in a capture level of 92.3%. Figure 15 shows that the temperature profile in the column is also affected by this change. The
228 temperature bulge moves towards the bottom of the column.

229 **6. Conclusions**

230 This paper presents a study of the CO₂ capture with MEA based on the dynamic modelling of the process. Two models
231 (equilibrium- and rate-based models) have been developed and compared. The rate-based approach yielded better
232 predictions compared with the equilibrium-based approach.

233 Dynamic analyses of dropping the upstream power plant load and the effect of increasing CO₂ loading in the lean solvent
234 were carried out. Simulation results reveal that the absorber operation is more sensitive to the L/G ratio than the actual flow
235 rates of the solvent and the flue gas. Increased CO₂ loading in the lean solvent resulted in significant reduction in absorber
236 performance.

237 **7. Future work**

238 It has been shown that the rate-based mass transfer model improves the predictions of the absorption process compared to
239 the equilibrium based model. Another rate controlling factor is the reaction chemistry. The kinetics of the chemical
240 absorption process would be improved by replacing the set of equilibrium reactions in the interface by kinetic and
241 equilibrium reactions in the liquid film (top right model in Figure 2). This should give a better prediction of the absorption
242 rates.

243 The stripper column model would subsequently be developed and the entire CO₂ capture facility model would be linked to
244 a coal-fired power plant model for whole plant analyses.

245 **References**

246 [1] Freund P. Making deep reductions in CO₂ emissions from coal-fired power plant using capture and storage of CO₂.
247 Proc. Inst. Mech. Eng. Part A J. Power Eng. 2003;217(1):1-8.

248 [2] Chalmers H, Gibbins J. Initial evaluation of the impact of post-combustion capture of carbon dioxide on supercritical
249 pulverised coal power plant part load performance. Fuel, 2007 9;86(14):2109-23.

250 [3] IEA GHG. The capture of carbon dioxide from fossil fuel fired power stations. 1993;IEA GHG/SR2.

251 [4] IPCC. IPCC special report on carbon dioxide capture and storage. 2005.

252 [5] Abu-Zahra MRM, Schneiders LHJ, Niederer JPM, Feron PHM, Versteeg GF. CO₂ capture from power plants: Part I. A
 253 parametric study of the technical performance based on monoethanolamine. *International Journal of Greenhouse Gas*
 254 *Control*, 2007 4;1(1):37-46.

255 [6] Aroonwilas A, Veawab A. Integration of CO₂ capture unit using single- and blended-amines into supercritical coal-
 256 fired power plants: Implications for emission and energy management. *International Journal of Greenhouse Gas Control*,
 257 2007 4;1(2):143-50.

258 [7] Davidson R. Post-combustion carbon capture from coal fired plants - solvent scrubbing. 2007;CCC/125.

259 [8] Davison J. Performance and costs of power plants with capture and storage of CO₂. *Energy*, 2007 7;32(7):1163-76.

260 [9] Kvamsdal HM, Jakobsen JP, Hoff KA. Dynamic modeling and simulation of a CO₂ absorber column for post-
 261 combustion CO₂ capture. *Chemical Engineering and Processing*, 2008; doi:10.1016/j.cep.2008.03.002.

262 [10] Kucka L, Müller I, Kenig EY, Górak A. On the modelling and simulation of sour gas absorption by aqueous amine
 263 solutions. *Chemical Engineering Science*, 2003 8;58(16):3571-8.

264 [11] Mahajani VV, Joshi JB. Kinetics of reactions between carbon dioxide and alkanolamines. *Gas Separation &*
 265 *Purification*, 1988 6;2(2):50-64.

266 [12] Vaidya PD, Kenig EY. CO₂-alkanolamine reaction kinetics: A review of recent studies. *Chemical Engineering and*
 267 *Technology* 2007;30(11):1467-74.

268 [13] E. Ross Dugas. Pilot plant study of carbon dioxide capture by aqueous monoethanolamine, M.S.E. Thesis, University
 269 of Texas at Austin; 2006.

270 [14] Kenig EY, Schneider R, Górak A. Reactive absorption: Optimal process design via optimal modelling. *Chemical*
 271 *Engineering Science*, 2001 1;56(2):343-50.

272 [15] Pintola T, Tontiwachukwuthikul P, Meisen A. Simulation of pilot plant and industrial CO₂ MEA absorbers. *Gas*
 273 *Separation & Purification* 1993;7(1):47-52.

274 [16] Alatiqi I, Sabri MF, Bouhamra W, Alper E. Steady-state rate-based modelling for CO₂/amine absorption—desorption
 275 systems. *Gas Separation & Purification* 1994;8(1):3-11.

276 [17] Al-Baghli NA, Pruess SA, Yesavage VF, Selim MS. A rate-based model for the design of gas absorbers for the
 277 removal of CO₂ and H₂S using aqueous solutions of MEA and DEA. Fluid Phase Equilibria, 2001 7/30;185(1-2):31-43.

278 [18] Schneider R, Kenig EY, Górak A. Dynamic Modelling of Reactive Absorption with the Maxwell-Stefan Approach.
 279 Chemical Engineering Research and Design, 1999 10;77(7):633-8.

280 [19] Schneider R, Sander F, Górak A. Dynamic simulation of industrial reactive absorption processes. Chemical
 281 Engineering and Processing, 2003 12;42(12):955-64.

282 [20] AspenTech. Rate-based model of the CO₂ capture process by MEA using Aspen Plus. 2008; Available at:
 283 <http://support.aspentech.com/>. Accessed May, 2008.

284 [21] Noeres C, Kenig EY, Górak A. Modelling of reactive separation processes: reactive absorption and reactive
 285 distillation. Chemical Engineering and Processing, 2003 3;42(3):157-78.

286 [22] B. A. Oyenakan. Modeling of Strippers for CO₂ capture by Aqueous Amines University of Texas at Austin; 2007.

287 [23] Vaidya PD, Mahajani VV. Kinetics of the Reaction of CO₂ with Aqueous Formulated Solution Containing
 288 Monoethanolamine, N-Methyl-2-pyrrolidone and Diethylene Glycol. Ind. Eng. Chem. Res. 2005;44(6):1868-73.

289 [24] Reid RC, Prausnitz JM, Sherwood TK. The properties of gases and liquids. Third ed. New York: McGraw-Hill; 1977.

290 [25] Onda K, Takeuchi H, Okumoto Y. Mass transfer coefficients between gas and liquid phases in packed columns.
 291 Journal of Chemical Engineering of Japan 1968;1(1):56-62.

292 [26] Kvamsdal HM, Rochelle GT. Effects of the temperature bulge in CO₂ absorption from flue gas by aqueous
 293 monoethanolamine. Ind. Eng. Chem. Res. 2008;47(3):867-75.

Table 1 Specifications for Equilibrium-based model

Description	Value
Number of equilibrium stages	7
Type of packing	IMTP
Packing material	Metal
Packing Dimension (m)	0.038
Packing height (m)	6.1
Condenser	None
Reboiler	None
Physical Property Method	Electrolyte NRTL

Table 2 Process conditions for Cases 32 and 47

	Case 47		Case 32	
Stream ID	FLUE	LEAN	FLUE	LEAN
	GAS	MEA	GAS	MEA
Temperature (K)	332.38	313.32	319.71	313.86
Pressure (10 ⁵ kPa)	1.033	1.703	1.035	1.703
Total flow (kg/s)	0.158	0.642	0.13	0.72
L/G ratio	4.6		6.5	
Mass-Fraction				
H ₂ O	0.0193	0.6334	0.0148	0.6334
CO ₂	0.2415	0.0618	0.2520	0.0618
MEA	0	0.3048	0	0.3048
N ₂	0.7392	0	0.7332	0

Table 3 Absorber column and packing data

Description	Value
Column inside diameter (m)	0.427
Height of packing (m)	6.1
Nominal packing size (m)	0.0381
Specific area (m ²)	145
Wetted area ratio	0.79

Table 4 Case 47 Process Conditions

	Pilot Plant	Equilibrium-	Rate-based
	Measurements	based model	model
Lean Solvent	0.281	0.281	0.281
loading (mol/mol)			
Rich Solvent	0.539	0.500	0.487
loading (mol/mol)			
CO ₂ Absorption	69	68.8	69.2
level (%)			
Flue gas flow rate	0.158	0.172*	0.172*
(kg/s)			

*Adjusted flue gas flow rate

Table 5 Case 32 Process Conditions

	Pilot Plant	Equilibrium- Measurements based model	Rate-based model
Lean Solvent	0.279	0.279	0.279
loading mol/mol			
Rich Solvent	0.428	0.469	0.464
loading mol/mol			
CO ₂ Absorption	95	97.8	94.4
level (%)			
Flue gas flow rate	0.13	0.12*	0.12*
(kg/s)			

*Adjusted flue gas flow rate

Table 6 Case 32 Process Conditions

	Pilot Plant	Equilibrium- Measurements based model	Rate-based model
Lean Solvent	0.279	0.279	0.279
loading mol/mol			
Rich Solvent	0.428	0.456	0.456
loading mol/mol			
CO ₂ Absorption	95	99.6	99.5
level (%)			
Flue gas flow rate	0.13	0.11*	0.11*
(kg/s)			

*Adjusted flue gas flow rate

Nomenclature

A	Cross sectional area (m^2)
c_t	Total molar concentration (mol/m^3)
F_i	Component mass flow rate (kg/s)
F_H	Enthalpy flow rate (J/s)
H	Enthalpy (J)
h	Specific Enthalpy (J/mol)
L	Height of column (m)
L/G	Liquid to gas
M	Mass Holdup (kg/m^3)
MW	Molecular weight (kg/mol)
N	Molar flux ($\text{mol}/\text{m}^2.\text{s}$)
n	Number of components
Sp	Specific area (m^2/m^3)
U	Energy Holdup (J/m^3)
x	Mass fraction
x_i^M	Molar fraction
y	Axial position
z'	Film position

Greek Symbols

δ	Film thickness (m)
----------	-------------------------------

μ	Viscosity (Pa.s)
ω	Wetted area ratio
χ	Diffusivity (m^2/s)

Subscripts

i	Component number
H	enthalpy
abs	Absorption

Superscripts

L	Liquid
V	Vapour
Lf	Liquid film
Vf	Vapour film
Lb	Liquid bulk
Vb	Vapour bulk
$cond$	Conduction
$conv$	Convection
I	Interface




Figure 1 Simplified process flow diagram of Chemical Absorption process for post combustion capture from [9]




Figure 2 Different levels of reactive absorption model complexity from [14]




Figure 3 Liquid and vapour Bulks, films and interface adapted from [21]




Figure 4 Absorber liquid temperature profile for case 47




Figure 5 Absorber liquid temperature profile for case 32




Figure 6 Absorber liquid temperature profile for case 32 with reduced flue gas flow




Figure 7 Flue gas and Lean MEA flow rate while reducing power plant load




Figure 8 CO₂ absorption level – Case A




Figure 9 Change in CO₂ absorption levels with L/G ratio




Figure 10 Temperature profile of absorber – Case A




Figure 11 CO₂ absorption level – Case B




Figure 12 Temperature profile of absorber – Case B




Figure 13 Increasing lean MEA CO₂ loading




Figure 14 CO₂ absorption level while increasing CO₂ loading of lean MEA




Figure 15 Temperature profile of absorber while increasing CO₂ loading of lean MEA



DSpace

<https://dspace.org/>

Dynamic modelling of CO₂ absorption for post combustion capture in coal-fired power plants

Lawal, Adekola; Wang, Meihong; Stephenson, Peter; Yeung, Hoi

2009-12-01T00:00:00Z

Elsevier Science B.V., Amsterdam.

<http://dx.doi.org/10.1016/j.fuel.2008.11.009>

A. Lawal, M. Wang, P. Stephenson, H. Yeung, Dynamic modelling of CO₂ absorption for post combustion capture in coal-fired power plants, Fuel, Volume 88, Issue 12, 7th European Conference on Coal Research and Its Applications, December 2009, Pages 2455-2462