

Off-design performance control and simulation for gas turbine engines with sequential combustors

Yi-Guang Li  and Yang Liu

Proc IMechE Part A:
J Power and Energy
2025, Vol. 0(0) 1–19
© IMechE 2025



Article reuse guidelines:
sagepub.com/journals-permissions
DOI: 10.1177/09576509251327695
journals.sagepub.com/home/pia



Abstract

A gas turbine engine with a sequential combustion system has the potential to offer high cycle efficiency at moderate turbine entry temperatures. Consequently, it has one more degree of power setting control, which offers more flexible but also more complex control of engine off-design operations. In this paper, a novel simulation method for off-design thermodynamic performance of sequential combustion gas turbines has been introduced and a novel performance control schedule for part-load operations at various ambient conditions have been proposed aiming to keep the relative workloads between the two turbine sections constant. The proposed control schedule is simple and can be adapted easily. By applying the off-design performance control schedule to a model industrial gas turbine engine with two sequential combustors, the performance of the model engine is simulated at different part-load and at different ambient conditions. The results show that by applying the proposed off-design performance control schedule, the model sequential combustion gas turbine engine could operate effectively at different part-load operating conditions and at different ambient conditions with both turbine sections keeping nearly constant workload distributions.

Keywords

Gas turbine, engine, reheat, sequential combustion, performance, simulation, control

Date received: 4 December 2024; accepted: 2 February 2025

Introduction

Modern gas turbine engines are based on Brayton cycle whose T - s diagram is shown in Figure 1(a). The cycle thermal efficiency of the gas turbine engines is mainly dominated by the cycle overall pressure ratio and the turbine entry temperature (TET). The higher the total pressure ratio and TET , the higher the cycle thermal efficiency. However, the conventional Brayton cycle engines seem to have reached their performance limits as the increase of TET is limited by the materials and cooling technology.

To improve the engine thermal efficiency further, one of the methods is to add extra energy during turbine expansion process known as sequential or reheat combustion while keeping the same maximum temperature throughout the combustion and expansion processes. As summarized by Yin and Rao,¹ there are two ways to apply such a cycle concept. One is to apply a constant temperature turbine burner ($CTTB$) introduced by Andriani et al.² and Andriani and Ghezzi³ where the combustion happens during the turbine expansion process, to make the cycle closer to Carnot cycle (isothermal heat addition) whose T - s diagram is shown in Figure 1(b). Further research in this direction have been reported by Sirignano and Liu⁴ and Sirignano et al.,⁵ Chiu et al.⁶ and Liu and Sirignano.⁷ It was concluded that $CTTB$ could produce more specific power and higher efficiency than the conventional gas turbines but the application of $CTTB$ engines is practically challenging as it is

difficult to burn fuel within a turbine expansion process. The other one is called Constant Pressure Turbine Burner ($CPTB$)^{7–12} where energy is added in additional combustors between turbine stages, that is inter-stage or sequential combustors. When the number of inter-stage combustors is increasing, it will become close to $CTTB$. Due to the feasibility in practical applications, most research on $CPTB$ focus on gas turbine engines with a single inter-stage combustor whose T - s diagram is shown in Figure 1(c). A comprehensive technology review of gas turbines with inter-stage turbine combustors is provided in 1.

The concept of the gas turbine engines with sequential combustors is practically demonstrated by the GT24/GT26 industrial gas turbine engines^{9,10} as shown in Figure 2. Due to the increase of O&M costs compared to traditional gas turbine engines, the application of the such gas turbine engines are limited nowadays. However, the benefits of performance improvements could outweigh the increased O&M costs when new demands or new applications of the

Faculty of Engineering and Applied Sciences, Cranfield University, Bedford, UK

Corresponding author:

Yi-Guang Li, Faculty of Engineering and Applied Sciences, Cranfield University, Cranfield, Bedford MK43 0AL, UK.

Email: i.y.li@cranfield.ac.uk




Figure 1. T-s diagram of gas turbine cycles (a) Conventional Brayton cycle (b) CTTB engine cycle (c) CPTB engine cycle.




Figure 2. GT24/GT26 gas turbines.^{9,10}

gas turbine engines with sequential combustors appear in the future.

Current gas turbine off-design performance simulation methods, demonstrated by modern software such as PROOSIS,¹³ GENENG,^{14,15} DYNEM,¹⁶ GasTurb,¹⁷ GSP,¹⁸ C-MAPSS,¹⁹ etc. only provide the simulation capability of gas turbine engines with a single combustor and therefore are not able to simulate the off-design performance of the engines with two sequential combustors. In addition, no publications have been found about off-design performance simulation and control methods for gas turbine engines with sequential combustors.

In this paper, a novel thermodynamic performance simulation method for the off-design performance of industrial single-shaft gas turbine engines with two sequential combustors is introduced. A novel off-design performance control schedule is proposed with an objective of controlling the gas turbine off-design operations effectively and keeping the relative workload

distribution between the two turbine sections constant for the benefits of good aerodynamic performance and balanced creep life consumption of the turbine sections. In addition, the proposed performance simulation method and the off-design performance control schedule are applied to a model gas turbine engine with two sequential combustors to demonstrate the effectiveness of the proposed method. Predicted performance of the model gas turbine engine, in particular the turbine entry temperatures of the two turbine sections, the workload distribution between the two turbine sections, the compressor IGV angle, and the engine thermal efficiency are shown and discussed, and conclusions are presented.

Methodology

This section introduces a novel thermodynamic performance simulation method and a new off-design performance control




Figure 3. Model gas turbine with sequential combustors.

schedule for single-shaft industrial gas turbine engines with two sequential combustors represented by [Figure 3](#).

Gas turbine off-design performance simulation approach

The off-design performance simulation approach proposed in this paper is an extension of the performance simulation approach based on thermodynamics for conventional gas turbines where the details can be found in [20](#). The corresponding software, Turbomatch²⁰ and Pythia²¹ have been developed at Cranfield over the past half century and validated against real engine data.^{22,23} Due to that sequential combustion engines have one more combustor resulting in the engine systems having one more dimensional of freedom, the off-design performance simulation approach has to be modified to deal with such complexity.

Performance simulations of a gas turbine engine normally start from the setting up of a performance model at a specified design operating condition where the configuration of the engine is decided and the component design parameters, such as compressor pressure ratio, turbine entry temperatures (TET), total air flow rate, power output, component efficiencies, pressure losses, cooling air flows, etc are given as input. Then, the design-point performance simulation can be conducted where the size of the engine and its components are determined, and the whole engine thermodynamic performance are calculated. This provides a starting point for the off-design performance simulations.

The off-design thermodynamic performance of the gas turbine engines refers to the performance of the gas turbine engines operating at different ambient and part-load

operating conditions where the characteristics of the major components, including compressors, combustors and turbines represented by component maps play a crucial role in engine performance behaviour. When an engine moves from one operating condition to another, the engine has to adapt itself to a new equilibrium condition where the conservation of mass and energy throughout the engine has to be satisfied. The control parameters that determine the operating conditions of the engine are called power setting parameters or handle parameters, such as shaft rotational speeds, turbine entry temperatures, shaft power output, etc. There is only one power setting parameter for conventional gas turbine engines. However, there are two power setting parameters for sequential combustion engines due to the adding of the 2nd combustor in the system.

To achieve the conservation of mass and energy in off-design performance calculations, the following two sets of parameters are normally identified for the engine thermodynamic system. The first one is a set of matching variables that determine the thermodynamic status of the gas turbine engine, including

- Variable z defined by Eq. (1) that specifies the relative position of the operating point on the relevant speed line of a compressor map.

$$z = \frac{PR_{sur} - PR}{PR_{sur} - PR_{chk}} \quad (1)$$

where PR is the pressure ratio at the operating point, PR_{sur} is the pressure ratio at the surge point of the same speed line of the operating point, and PR_{chk} the pressure ratio at the choke point of the same speed line of the operating point, shown in [Figure 4](#).




Figure 4. Characteristic map of compressor with variable IGV.

- Turbine Entry Temperature (TET)
- Shaft relative rotational speed PCN of compressor defined as the ratio between the shaft rotational speed at any operating condition and the shaft rotational speed at design operating condition where $PCN = N/N_{DP}$
- Shaft power output W_{shaft} of each turbine
- Non-dimensional mass flow rate TF of each turbine section where $TF = mP/\sqrt{T}$

The second set of parameters is the matching errors of the gas turbine engines that are used to assess the conservation of mass and energy within the whole engine systems, including

- Error δm_c of compressor mass flow defined by Eq (2) as the difference between the actual mass flow rate m_c coming from the upstream of a compressor and the mass flow rate that can be swallowed by the compressor obtained from the compressor map $m_{c,map}$

$$\delta m_c = (m_c - m_{c,map}) / m_{c,map} \quad (2)$$

- Error δTF of turbine non-dimensional mass flow rate TF defined by Eq. (3) as the difference between the actual non-dimensional mass flow rate coming from the upstream of a turbine and the non-dimensional mass flow rate that can be swallowed by the turbine obtained from the turbine map TF_{map}

$$\delta TF = (TF - TF_{map}) / TF_{map} \quad (3)$$

- Error δDH of turbine enthalpy drop defined by Eq. (4) as the difference between the actual work DH that all turbine sections on the same shaft should jointly deliver, including the work consumed by compressors and the auxiliary systems on the same shaft, and the work DH_{map} that all turbine sections can deliver which is the summation of the work obtained from each map of all turbine sections

$$\delta DH = (DH - DH_{map}) / DH_{map} \quad (4)$$

- Error δP_{exd} of exhaust duct to measure the mass continuity at the exhaust duct, defined by Eq. (5) as the difference between the total pressure P_{exd} of incoming mass flow of a exhaust duct and the total pressure P_{req} needed to drive the in-coming mass flow through the exhaust duct

$$\delta P_{exd} = (P_{exd} - P_{req}) / P_{req} \quad (5)$$

Not all of the above matching variables and errors are required for the off-design performance calculations of all gas turbine engines. The selection of them depends on the type of engines, the selection of power setting parameter(s) and the off-design performance control schedule. To ensure a unique solution at an off-design operating point, the number of matching variables denoted as N_V must be equal to the number of matching errors, denoted as N_E , represented by Eq. (6).

$$N_V = N_E \quad (6)$$

Figure 3 shows the gas turbine engine in concern with a set of matching variables, a set of marching errors and a set of power setting parameters. More discussions on the selection of these parameters will be given in the next section.

As a gas turbine engine is a non-linear and complex thermodynamic system, the matching errors $\vec{E}$ may be represented by an implicit non-linear function of the matching variables $\vec{V}$ shown by Eq. (7).

$$\vec{E} = f(\vec{V}) \quad (7)$$

When an engine moves from its initial operating point denoted with subscript “0” to a new off-design operating point, a Taylor series expansion may be applied to Eq. (7) and its linearized Eq. (8) may be obtained by ignoring high order terms.

$$dE_i = \left(\sum_{j=1}^{N_{VE}} \frac{\partial E_i}{\partial V_j} \right)_0 \cdot dV_j, (i = 1, 2, \dots, N_{VE}) \quad (8)$$

A solution may be obtained by solving Eq. (8) and the new values of the matching variables may be obtained by Eq. (9).

$$V_j = (V_j)_0 + dV_j, (j = 1, 2, \dots, N_{VE}) \quad (9)$$

Because of the non-linearity of engine performance behavior, the solutions from the linearized Eq. (8) may have large prediction errors. Therefore, Newton Raphson iterative approach shown in Figure 5 may be applied to get a converged solution when the matching errors become significantly small. It is worth mentioning that under-relaxation may be used in the Newton Raphson iteration process in order to enhance the convergence of the predictions.

Off-design performance control strategy

As stated in the early sections, a sequential combustion gas turbine engine shown in Figure 3 has two power setting




Figure 5. Newton Raphson iterations.

parameters due to the addition of an extra inter-stage combustor. This results in more flexibility but also more complexity in engine off-design performance control compared with conventional gas turbine engines having only one power setting parameter.

The two power setting parameters may be chosen from the following parameters:

- Turbine shaft power output ($W_{shaft} = W_{shaft,HP} + W_{shaft,LP}$)
- Shaft relative rotational speed (PCN)
- Turbine entry temperature of the turbine HP section (TETHP)
- Turbine entry temperature of the turbine LP section (TETLP)

For a single-shaft industrial gas turbine engine with sequential combustors, the selection of the power setting parameters in two special scenarios may be considered:

- The operation of the engine is to meet the external power demand. Therefore, the turbine shaft power output (W_{shaft}) may be chosen as one of the power setting parameters so the power output can vary based on external power demand.
- If the engine is used for electricity power generation, the engine may be connected to a national grid via a gearbox so the shaft rotational speed must be kept constant to ensure output speed at either 3000 rpm or 3600 rpm depending on the frequency of the grid. Therefore, the shaft rotational speed at part-load operating conditions should be kept constant and cannot be used as a power setting parameter.

With the above considerations in mind, the following two off-design performance control schedules are investigated and their impact on engine performance are simulated and analyzed:

Control schedule 1: W_{shaft} – TETHP control. With this control schedule, W_{shaft} and TETHP are chosen as the two power setting parameters while TETLP is set as a matching

variable and changes together with other matching variables to satisfy the conservation of mass and energy. By using this control schedule during part-load operations, the shaft power can be controlled depending on external power demands while TETHP may be set as a function of the shaft power. The variations of TETLP are closely coupled with TETHP and the two combustors must work together to produce enough thermal energy to drive the two turbine sections and to meet the total power demand. In addition, the temperatures TETHP and TETLP indicate the amount of energy added to each of the combustors. By controlling the two combustor exit temperatures TETHP and TETLP, that is controlling the fuel flow rates of the two combustors, the relative power distributions between the turbine HP section and the turbine LP section can be effectively controlled. As shown in Figure 6 where TETHP and TETLP vary with the decrease of the shaft power, if the decreasing rate of TETHP is small (such as line a1 indicating less reduction of fuel flow into the main combustor), the decreasing rate of TETLP will be large (such as line a2 indicating more reduction of fuel flow into the inter-stage combustor) to meet the required total amount of energy required, and vice versa (such as lines c1 and c2).

Control schedule 2: W_{shaft} – TETLP control. With this control schedule, W_{shaft} and TETLP are chosen as the two power setting parameters, and TETHP is set as a matching variable and changes together with other matching variables to satisfy the conservation of mass and energy. By using this control schedule during part-load operations, the shaft power can be controlled based on external power demands and TETLP may be set as a function of the shaft power. The variation of TETHP are also closely coupled with TETLP and the two combustors must produce enough thermal energy to drive the two turbine sections and meet the total power demands. As shown in Figure 6 where TETHP and TETLP vary with the decrease of the shaft power, if the decreasing rate of TETLP is small (such as line c2 indicating less reduction of fuel flow into the inter-stage combustor), the decreasing rate of TETHP will be large (such as line c1 indicating more reduction of fuel flow into the main combustor), and vice versa (such as lines a2 and a1).

As TETHP and TETLP are closely coupled, the Control Schedules 1 and 2 are equivalent from performance perspective. Therefore, in this study only W_{shaft} – TETHP control schedule is chosen for further study.

As the objective of having an inter-stage combustor to split the turbine into two sections is to make the thermal cycle of the gas turbine engine closer to Carnot cycle as shown in Figure 1(b), the expansion ratio of the turbine HP section should be lower than that of the turbine LP section as shown in Figure 1(c). If the expansion ratio of the turbine LP section is much higher than that of the turbine HP section, which is the case in this study, the turbine LP section would generate much more shaft power than that of the turbine HP section. As the gas turbine engine works in a wide range of ambient and operating conditions, it is desirable that the two turbine sections keep more or less the same relative distribution of workloads at all off-design operating conditions. Therefore, the turbine entry




Figure 6. Off-design control schedule – TETHP & TETLP varying with shaft power.

temperatures of the two turbine sections should change in a certain way to ensure such desire is satisfied, which would be beneficial to both the aerodynamic performance and the balanced creep life consumption of the two turbine sections. For that purpose, load coefficients to measure the share of the workload of the two turbine sections are introduced and defined by Eqs. (10) and (11)

$$\alpha_i = \frac{W_{shaft,i}}{W_{shaft}}, (i = HP, LP) \quad (10)$$

$$\alpha_{HP} + \alpha_{LP} = 1 \quad (11)$$

where α_{HP} is the load coefficient of the turbine HP section, $W_{shaft,HP}$ is the workload of the turbine HP section, α_{LP} is the load coefficient of the turbine LP section, and $W_{shaft,LP}$ is the workload of the turbine LP section.

In general, the power setting parameters W_{shaft} and $TETHP$ are independent from each other so the options of controlling the sequential combustion engine operations are unlimited. To make the engine control easier in applications as mentioned earlier, $TETHP$ may vary as a function of W_{shaft} in a way that the load distributions between the two turbine sections indicated by the load coefficients α_{HP} and α_{LP} are kept constant. As the load distributions of the two turbine sections cannot be directly measured and controlled easily, they need to be controlled indirectly by controlling the fuel flow rates or the energy input to the two combustors, which can be achieved by controlling the two turbine entry temperatures $TETHP$ and $TETLP$. Due to that the gas turbine engines are complicated non-linear thermodynamic systems, trials-and-errors are needed by running the engine performance model to find a good functional relationship between $TETHP$ and W_{shaft} to ensure that the two turbine sections always keep the same relative load distributions indicated by constant values of α_{HP} and α_{LP} at all off-design operating conditions. Consequently, the variations of $TETLP$ against the $TETHP$ - W_{shaft} control schedule can be established. From the engine control perspective, controlling $TETHP$ and $TETLP$ is equivalent to controlling the fuel flow rates to the two combustors and also equivalent to the control of the relative distributions of power between the two turbine sections. In practice, although these two turbine entry temperatures are too high to be measured directly, they can be predicted thermodynamically by using the

measurements of the turbine exit temperatures and energy balance calculations.

In addition, ambient conditions mainly represented by ambient pressure and temperature, determine the density of ambient air and have a significant impact on engine air flow rate and consequently shaft power output. To consider the impact of changing ambient conditions, $TETHP$ may be controlled as a function of $W_{shaft} \cdot \frac{\theta}{\delta}$ represented by Eq. (12)

$$TETHP = f\left(W_{shaft} \cdot \frac{\theta}{\delta}\right) \quad (12)$$

$$\theta = \frac{T_{amb}}{T_{amb,ref}} \quad (13)$$

$$\delta = \frac{P_{amb}}{P_{amb,ref}} \quad (14)$$

where θ is ambient temperature ratio, δ is ambient pressure ratio, $(W_{shaft} \cdot \frac{\theta}{\delta})$ is corrected shaft power. The inclusion of $\frac{\theta}{\delta}$ is because the engine power output is proportional to ambient air density that is inversely proportional to ambient temperature (θ) and proportional to ambient pressure (δ). Therefore, the variation of the two TETs should be proportional to the ambient temperature (θ) and inversely proportional to the ambient pressure (δ).

For each gas turbine engine, trials and errors may be conducted to find the best functional relationship between $TETHP$ and $W_{shaft} \cdot (\theta/\delta)$ to ensure constant load coefficients α_{HP} and α_{LP} at all off-design operating conditions as shown in Figure 7. To make the control schedule simple, a linear relationship between $TETHP$ and $W_{shaft} \cdot (\frac{\theta}{\delta})$ is suggested in this study as shown by Eq. (15) and represented by Figure 8. For different engines, the coefficients a and b may be different, and trials and errors by running the engine model are necessary to find their best values and obtain Figure 8 aiming to keep constant turbine load coefficients α_{HP} and α_{LP} .

$$TETHP = a \cdot W_{shaft} \cdot \frac{\theta}{\delta} + b \quad (15)$$

As gas turbine engines are nonlinear thermodynamic systems, such simplicity in designing the control schedule would benefit the implementation of the control schedule but the turbine load coefficients may be kept close to but not exactly constant at all off-design operating conditions.

Once Eq. (15) becomes available, the functional relationships between $TETHP$, $TETLP$ and $W_{shaft} \cdot (\frac{\theta}{\delta})$ can be established and represented by Figure 8. Consequently, the off-design performance control system can be set up and such control system may be schematically shown by Figure 9 with the following explanations:

- W_{shaft} is the 1st power setting parameter, and its value is determined by the external power demand.
- $TETHP$ is the 2nd power setting parameter, and its value is determined by Eq. (15) or Figure 8.
- The value of $TETLP$ can be obtained from Figure 8 based on $W_{shaft}(\theta/\delta)$.




Figure 7. Load coefficients versus corrected shaft power.

- The fuel flow rates to the main combustor $m_{f,mc}$ and to the inter-stage combustor $m_{f,ic}$ are regulated by reducing the errors between the set values of $TETHP$ and $TETLP$ from predictions and their measured values from the engine, respectively with a control method, such as PID.

Based on the suggested off-design performance control schedule, the following are some discussions for different scenario of ambient conditions for the engine to deliver required shaft power:

- At a constant ambient condition where θ and δ are constant, $TETHP$ increases when W_{shaft} increases, and vice versa. This is because high demand of power output requires high fuel input so the engine has to run at a high $TETHP$, and vice versa.
- At a constant demand of power output W_{shaft} and a rising ambient temperature, $TETHP$ has to increase to keep the power output unchanged. This is echoed in Figure 8 where the rising ambient temperature make the corrected shaft power parameter $W_{shaft} \cdot (\theta/\delta)$ larger, requiring an increase of $TETHP$. Similarly, $TETHP$ will decreases to keep shaft power unchanged when ambient temperature drops.
- At a constant demand of power output W_{shaft} and a rising ambient pressure, $TETHP$ has to decrease to keep the shaft power unchanged. This is also indicated in Figure 8 where the corrected shaft power $W_{shaft} \cdot (\theta/\delta)$ decreases when ambient pressure increases, requiring a decrease of $TETHP$. Similarly, $TETHP$ increases when ambient pressure decreases.
- In a situation where both ambient pressure and temperature change simultaneously, $TETHP$ varies depending on the combined effect of ambient pressure and temperature on the corrected shaft power. In other words, $TETHP$ increases when $(\theta/\delta) > 1$, and vice versa to keep the shaft power W_{shaft} unchanged, as shown in Figure 8.

Modern single shaft gas turbines have variable IGV to ensure high TET and therefore high thermal efficiency at part load operating conditions, and so is this model engine. In other words, the compressor IGV of the model engine is




Figure 8. $TETHP - W_{shaft} \cdot (\theta/\delta)$ control schedule.

set to close when the engine power output decreases. The control schedule of the IGV angle used in this study is shown in Eq. (16) where the IGV angle is a function of the referred relative total shaft power of the two turbine sections. Such a IGV control schedule may be chosen based on the compressor map and desired engine performance to ensure that the compressor air flow rate is reduced by closing the IGV when engine shaft power output reduces.

$$IGV = f(\beta) \quad (16)$$

$$\beta = \frac{W_{shaft}/W_{shaft,DP}}{\delta\sqrt{\theta}} \quad (17)$$

where IGV represents the angle of compressor inlet guide vanes, β is referred relative total shaft power, W_{shaft} is shaft power, and $W_{shaft,DP}$ is the shaft power at design operating condition.

Demonstration of applications

The introduced engine off-design performance simulation method and performance control schedule have been implemented into Cranfield gas turbine performance and gas path diagnostics software, Pythia²¹ and applied to a model single-shaft industrial gas turbine engines with sequential combustors similar to GT24/26 to demonstrate the application of the methods.

Model engine

A performance model for the model sequential combustion gas turbine engine was set up for the study. The model engine has one compressor, one main combustor followed by two turbine sections on the same shaft with an inter-stage reheat combustor in between. The configuration of the model engine is shown in Figure 3 and its performance specification at standard sea level static ISA condition is shown in Table 1. It is assumed that

- W_{shaft} and $TETHP$ are the two engine power setting parameters based on the discussions in Section “Off-design performance control strategy”,
- The shaft rotational speed is kept constant at off-design operating conditions assuming that the gas




Figure 9. Schematic engine control system.

Table 1. Performance specification of model engine at standard sea level static ISA condition.

Parameter	Value	Symbol	Unit
Shaft power output	165	W_{shaft}	MW
Thermal efficiency	40		%
Total pressure ratio	30	PR	
Compressor isentropic efficiency	88		%
Isentropic efficiency of both turbine sections	90		%
TET of turbine HP section	1400	$TETHP$	K
TET of turbine LP section	1500	$TETLP$	K
Air flow rate	368		kg/s
Load coefficient of turbine HP section	22.75	α_{HP}	%
Load coefficient of turbine LP section	77.25	α_{LP}	%

Table 2. Selected matching variables of model engine.

1	Z	Parameter indicating compressor operating point defined by Eq. (1)
2	$TETLP$	Turbine entry temperature of turbine LP section
3	$TFHP$	Non-dimensional mass flow rate of turbine HP section
4	$TFLP$	Non-dimensional mass flow rate of turbine LP section

Table 3. Selected error parameters of model engine.

$\delta TFHP$	Error of non-dimensional mass flow rate of turbine HP section to measure mass conservation
$\delta TFLP$	Error of non-dimensional mass flow rate of turbine LP section to measure mass conservation
δDH	Error of shaft workload for both turbine sections to measure energy conservation
δP_{exd}	Error of exhaust duct total pressure to measure exhaust duct mass conservation




Figure 10. Off-design performance control schedule.




Figure 11. IGV control schedule.

turbine engine is used for electricity generation and connected to a national grid.

- The shaft power output can increase, decrease, or keep constant depending on external power demands.
- The two turbines are air cooled with 10% air extracted from the exit of the compressor for the cooling of the turbine HP section and 7% air extracted from the 50% pressure ratio position of the compressor for the cooling of the turbine LP section.

Off-design performance simulation and control schedule

To simulate the off-design performance of the model sequential combustion engine, four matching variables shown

in Table 2 that determine the performance status of the engine are chosen and four matching errors shown in Table 3 that are used to check the conservation of mass and energy are selected.

Newton Raphson iteration method described in Section “Gas turbine off-design performance simulation approach” is used to obtain a converged solution when the model engine moves from one off-design operating point to another.

The off-design performance control schedule presented in Section “Off-design performance control strategy” is used to set up a functional relationship between the two power setting parameters, W_{shaft} and $TETHP$. To keep the turbine load coefficients (α_1 and α_2) constants at all off-design operating conditions as shown in Figure 7, trials and errors have been conducted and a linear temperature control




Figure 12. TETs vs relative shaft power ($T_{amb} = 15^\circ\text{C}$ & $P_{amb} = 1 \text{ atm}$).




Figure 13. IGV Angle versus relative shaft power ($T_{amb} = 15^\circ\text{C}$ & $P_{amb} = 1 \text{ atm}$).

schedule shown in Eq. (18) and Figure 10 is found to be suitable where the impact of ambient conditions is considered by $(\frac{\theta}{\delta})$.

$$TETHP = 5 \cdot W_{shaft} \cdot \frac{\theta}{\delta} + 575 \quad (18)$$

The IGV angle is controlled by a control schedule shown in Figure 11 that take a special form of Eq. (16) where the IGV angle keeps 0 when the referred relative shaft power β is above 1 and reduces when β is below 1.

To assess if the proposed control schedules could satisfactorily control the turbine load coefficients at constant values at different off-design operating conditions, the following four test cases are conducted.

Test case 1: Impact of part-load operations

In this test case, it is assumed that the ambient condition is constant and at the standard sea level static ISA condition where $T_{amb} = 288.15\text{K}$ and $P_{amb} = 1 \text{ atm}$. Correspondingly, $\theta = 1$ and $\delta = 1$. It is also assumed that the gas




Figure 14. Air flow rate versus relative shaft power ($T_{amb} = 15^{\circ}\text{C}$ & $P_{amb} = 1 \text{ atm}$).




Figure 15. Load coefficients versus relative shaft power ($T_{amb} = 15^{\circ}\text{C}$ & $P_{amb} = 1 \text{ atm}$).

turbine generates and supplies electric power to a national grid between 100 MW and 195 MW (61%–118.2% of power at design condition).

When the model engine delivers shaft power from 195 MW to 100 MW, the performance of the engine is simulated with its performance model following the off-design performance control schedule shown in Figure 10 and the IGV control schedule shown in Figure 11, and the results are shown in Figures 12–16. It can be seen in Figure 12 that *TETLP* reduces almost in parallel with

TETHP. The IGV angle variation shown in Figure 13 results in the engine air flow rate only reducing from 395 kg/s at and above design power to about 300 kg/s at 100 MW as shown in Figure 14. Consequently, the load coefficient α_{HP} and α_{LP} are kept almost constant around 0.23 and 0.77 respectively as shown in Figure 15, and the thermal efficiency changes from 41.1% at 195 MW to 34.9% at 100 MW as shown in Figure 16. It demonstrates that the chosen off-design control schedule shown in Figure 10 works well to keep the workload distribution




Figure 16. Thermal efficiency versus relative shaft power ($T_{\text{amb}} = 15^\circ\text{C}$ & $P_{\text{amb}} = 1 \text{ atm}$).




Figure 17. TETs versus ambient temperature ($P_{\text{amb}} = 1 \text{ atm}$).

between the two turbine sections almost constant at the standard sea level static ISA condition. Such a control schedule could ensure that the aerodynamic load distributions between the two turbine sections are kept almost unchanged and the two turbine sections would have balanced creep life consumption.

Test case 2: Impact of ambient temperature

This test case is used to assess the impact of changing ambient temperature on the performance of the model gas turbine at different power levels while keeping the ambient pressure constant at 1 atm. Two levels of

power output are considered in the analysis, one at the design load of 165 MW and the other at a part load of 120 MW.

To keep the power output constant, both *TETHP* and *TETLP* have to increase when ambient temperature increases resulting in the drop of ambient air density, and vice versa. Figure 17 shows how *TETHP* of the model engine vary with the ambient temperature between -25°C and 35°C based on the control schedule shown in Figure 10 and how *TETLP* responds accordingly. It can be seen in Figure 17 that *TETHP* and *TETLP* cross over when ambient temperature decreases. At the part load of 120 MW, both *TETHP* and *TETLP* become lower than those at the design power of 165 MW and vary with ambient temperature in a




Figure 18. IGv angle versus ambient temperature ($P_{amb} = 1 \text{ atm}$).




Figure 19. Load coefficients varying with ambient temperature ($P_{amb} = 1 \text{ atm}$).

similar way as those at the design power. The gap of $TETHP$ between the two power levels is bigger than that of $TETLP$, with the gap of around 70K for $TETHP$ and around 40K for $TETLP$.

As shown in Figure 18, at high power output of 165 MW the IGv angle is kept 0° at ambient temperature below 15°C and start to decrease when the ambient temperature is above 15°C . At low power output of 120 MW, the IGv angle is kept decreasing when the ambient temperature increases.

The turbine load coefficients α_1 and α_2 shown in Figure 19 have noticeable changes, with α_1 changing

between 0.21 and 0.26 and α_2 changing between 0.79 and 0.74, with an absolute variation of around 0.054. As the baseline load coefficient of the turbine HP section is much lower than that of the turbine LP section, the relative variation of the load coefficient is 23.6% for the turbine HP section and is 7.0% for the turbine LP section.

As the result of the chosen TET and IGv angle controls, the thermal efficiency of the engine has modest drops from 42.8% to 38.5% at 165 MW and from 38.7% to 35.9% at 120 MW when ambient temperature increases from -25°C to 35°C as shown in Figure 20.




Figure 20. Thermal efficiency versus ambient temperature.




Figure 21. TET varying with ambient pressure ($T_{amb} = 288.15$ K).

Test case 3: Impact of ambient pressure

This test case is used to assess the impact of changing ambient pressure on the performance of the model gas turbine at different power levels while keeping the ambient temperature constant at 288.15 K. Two levels of power output are considered, one at the full load of 165 MW and the other at a part load of 120 MW.

To keep the power output constant, $TETHP$ and $TETLP$ have to increase when ambient pressure drops, and vice versa. Figure 21 shows the variation of $TETHP$ and $TETLP$ corresponding to the ambient pressure variation between 0.7 and 1.4 atm where $TETHP$ and $TETLP$ changes almost in parallel. At the part load of 120 MW, $TETHP$ and $TETLP$ become lower than those at the

design power and they vary with ambient pressure in a similar way as those at design power of 165 MW. It can also be seen in the figure that the gaps between $TETHP$ and $TETLP$ becomes slightly smaller when ambient pressure drops, changing from 136K at ambient pressure of 1.2 atm to 100K at ambient pressure of 0.9 atm at the design power of 165 MW, and from 120K at ambient pressure of 1.2 atm to 100K at ambient pressure of 0.7 atm at the part load of 120 MW.

The IGV angle decreases when the ambient pressure increases as shown in Figure 22 except in the situation where the IGV is kept 0° when the ambient pressure is below 1 atm at 165 MW. Consequently, the turbine load coefficients α_1 and α_2 are kept almost constant, with α_1 at around 0.23 and with α_2 at around 0.77, with an absolute




Figure 22. IGV angle versus ambient pressure.




Figure 23. Load coefficient varying with ambient pressure ($T_{amb} = 288.15$ K).

variation of around 0.004 as shown in Figure 23. Due to the significant difference in the absolute values of the baseline load coefficients between the two turbine sections, the relative variation of the load coefficient is 1.8% for the turbine HP section and is 0.5% for the turbine LP section.

The thermal efficiency of the engine is kept at high level as shown in Figure 24, with a modest drop from 40.7% to 36.9% at 165 MW when the ambient pressure increases from 0.9 to 1.4 atm, and from 40.4% to 34.9% at 120 MW when the ambient pressure increases from 0.7 to 1.2 atm.

Test case 4: Impact of both ambient pressure and temperature

Depending on geographical locations and seasons, ambient pressure and temperature may vary significantly. To demonstrate that the proposed control schedule works for industrial gas turbine engines working at extreme ambient conditions, the ambient condition at La Paz, the capital city of Bolivia is chosen for the analysis. It is the highest city in the world located at the altitude of 3650 m above sea level and the average yearly temperature changes between -3°C




Figure 24. Thermal efficiency versus ambient pressure.




Figure 25. TETs varying with relative shaft power ($T_{amb} = 5^\circ\text{C}$ & $P_{amb} = 0.7$ atm).

and 17°C and the average ambient pressure is around 0.7 atm.

In this case study, it is assumed that the ambient temperature is 5°C and the ambient pressure is 0.7 atm. Due to the high altitude where the ambient pressure and air density are low, the model engine may deliver much lower shaft power than at sea level static ISA condition. Therefore, it is assumed that the model engine is run from 125 MW to 75 MW (75.8% to 45.5% of power at design condition) and $TETHP$ is controlled following the control schedule shown in Figure 10.

Figure 25 shows how $TETHP$ vary with the shaft power output and how $TETLP$ responds accordingly. It can be seen in the figure that $TETHP$ changes almost linearly with the shaft power while $TETLP$ changes almost in parallel with $TETHP$. In other words, the gap between $TETHP$ and $TETLP$ increases from about 30K to about 80K when the shaft power changes from 125 MW to 75 MW (75.8% to 45.5% of design power). IGV angle is kept 0° from 125 to 115 MW (75.8% to 69.7% of design power) and then gradually decreases to -24° when the shaft power drops to 75 MW (45.5% of design power), as shown in Figure 26.




Figure 26. IGV angle versus relative shaft power.




Figure 27. Load coefficients varying with relative shaft power ($T_{\text{amb}} = 5^\circ\text{C}$ & $P_{\text{amb}} = 0.7$ atm).




Figure 28. Thermal efficiency versus relative shaft power.

Figure 27 shows the load coefficients α_1 and α_2 are kept almost constant when the shaft power changes, with the load coefficient of the turbine HP section α_1 at around 0.24 and the load coefficient of the turbine LP section at around 0.76. It shows that even at such a high-altitude city, the load coefficients of the two turbine sections can still be kept almost constant.

The thermal efficiency of the engine is kept at high level with a modest decrease from 41.3% at the shaft power of 125 MW (75.8% of design power) to 36.2% at the shaft power of 75 MW (45.5% of design power) as shown in Figure 28.

Conclusions

The paper introduces a novel off-design performance simulation method for single-shaft industrial gas turbine engines with sequential combustors where two power setting parameters are considered, one is the shaft power output and the other is the turbine entry temperature of the turbine HP section. Correspondingly, a novel off-design performance control schedule is proposed where the entry temperature of the turbine HP section is set as a linear function of the corrected shaft power output aiming to keep the load distribution between the two turbine sections reasonably constant. A compressor IGV control schedule where the IGV angle is a function of referred relative shaft power is also introduced to reduce compressor air flow rate and keep engine thermal efficiency high at part load operating conditions. Such an off-design performance control schedule is simple, easy for implementation and is able to ensure that the gas turbine engines can meet external power demands, control the engine off-design performance effectively, keep the workload distribution between the two turbine sections reasonably constant and maintain high thermal efficiency at all off-design operating conditions.

The introduced performance simulation method and the off-design control schedule have been applied to a model industrial gas turbine engine with sequential combustors operating at different ambient and off-design operation conditions to demonstrate the effectiveness of the methods. The simulation results in the four test cases show that the workload distribution between the two turbine sections can be kept reasonably constant at different part-load and ambient conditions. The ambient temperature has more impact on the workload distribution between the two turbine sections than the ambient pressure within the scope of discussions. In other words, the variation of around 0.052 of the load coefficient would happen due to ambient temperature variation between -25°C and 35°C , compared to the variation of around 0.004 of the load coefficient due to ambient pressure variation between 0.7 atm and 1.2 atm. Consequently, the variation of ambient temperature could result in 23.6% relative variation of the load coefficient in the turbine HP section and 7.0% in the turbine LP section as the baseline value of the load coefficient of the turbine HP section (0.2278) is much lower than that of the turbine LP section (0.7722).

Declaration of conflicting interests

The author(s) declared no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

Funding

The author(s) disclosed receipt of the following financial support for the research, authorship, and/or publication of this article: The work was self-funded by Cranfield University.

ORCID iD

Yi-Guang Li  <https://orcid.org/0000-0002-9011-8226>

References

1. Yin F and Rao AG. A review of gas turbine engine with inter-stage turbine burner. *Prog Aero Sci.* 2020; 121: 100695. doi: [10.1016/j.paerosci.2020.100695](https://doi.org/10.1016/j.paerosci.2020.100695).
2. Andriani R, Ghezzi U and Ferri Degli Antoni L. Jet engines with heat addition during expansion: a performance analysis. *AIAA-99-0744, 37th AIAA aerospace sciences meeting and exhibit.* Reno, NV, USA, 1999.
3. Andriani R and Ghezzi U. Off-design analysis of constant temperature turbine jet engine. *AIAA-2002-3766, 38th IAA/ASME/SAE/ASEE Joint Propulsion Conference & Exhibit.* Indiana, USA, 2002.
4. Sirignano WA and Liu F. Performance increases for gas-turbine engines through combustion inside the turbine. *J Propul Power.* 1999; 15(1): 111–118. doi: [10.2514/2.5398](https://doi.org/10.2514/2.5398).
5. Sirignano WA, Delplanque JP and Liu F. Selected challenges in jet and rocket engine combustion research. *33rd Joint Propulsion Conference and Exhibit.* Seattle, USA, 1997.
6. Chiu Y-T, King PS and O'Brien WF. A performance study of a super-cruise engine with isothermal combustion inside the turbine. *41st AIAA/ASME/SAE/ASEE Joint Propulsion Conference & Exhibit.* Arizona, 2005.
7. Liu F and Sirignano WA. Turbojet and turbofan engine performance increase through turbine burners. *J Propul Power.* 2001; 17(3): 695–705. doi: [10.2514/2.5797](https://doi.org/10.2514/2.5797).
8. Liew KH, Urip E and Yang SL. Parametric cycle analysis of a turbofan engine with an interstage turbine burner. *J Propul Power.* 2005; 21(3): 546–551. doi: [10.2514/1.2546](https://doi.org/10.2514/1.2546).
9. Joos F, Brunner P, Schulte-Werning B, et al. Development of the sequential combustion system for the ABB GT24/GT26 gas turbine family. *ASME 96-GT-315, ASME 1996 International Gas Turbine and Aeroengine Congress and Exhibition.* Birmingham, UK, 1996.
10. Joos F, Brunner P, Stalder M, et al. Field experience of the sequential combustion system for the GT24/GT26 gas turbine family. *ASME 98-GT-220, ASME 1998 International Gas Turbines and Aeroengine Congress and Exhibition.* Stockholm, Sweden, 1998.
11. Gronstedt T and Avellan R. Mission analysis of an inter-turbine burning turbofan engine. *20th International Symposium on Air Breathing Engines (ISABE).* Gothenburg, Sweden, 2011.
12. Chen G, Hoffman MA and Davis RL. Gas turbine performance improvements through the use of multiple turbine interstage burners. *J Propul Power.* 2004; 20(5): 828–834. doi: [10.2514/1.2886](https://doi.org/10.2514/1.2886).
13. Bala A, Sethi V, Lo Gatto E, et al. PROOSIS – a collaborative Venture for gas turbine performance simulation using an object oriented programming schema. *ISABE 2007-1357* 2007.
14. Koenig RW and Fishbach LW. *GENENG – a program for calculating design and off design performance for turbojet and turbofan engines.* NASA, 1972. TN D-6552.

15. Fishbach LW and Koenig RW. A program for calculating design and off design performance of two and three-spool turbofans with as many nozzles. NASA, 1973, vol TN D-6553.
16. Sellers JF and Daniele CJ, "DYNGEM - a program for calculating steady state and transient performance of turbojet and turbofan engines", NASA TN D-7901, 1975.
17. Kurzke J. "Advanced user-friendly gas turbine performance calculations on a personal computer", 95-GT-147. Houston, Texas, USA: ASME International Gas Turbine and Aero-engine Congress and Exposition, 1995.
18. Visser WPJ and Broomhead MJ. "GSP, a generic object-oriented gas turbine simulation environment", 2000-GT-0002, ASME Turbo Expo 2000. Munich, Germany, 2000.
19. Frederick DK, DeCastro JA and Litt JS, "User's guide for the commercial modular aero-propulsion system simulation (C-MAPSS)", NASA TM-215026, 2007.
20. MacMillan WL. *Development of a modular-type computer program for the calculation of gas turbine off-design performance*. Cranfield Institute of Technology, 1974. PhD thesis.
21. Li YG and Singh R. An advanced gas turbine gas path diagnostic system - PYTHIA. *ISABE-2005-1284, the Seventeenth International Symposium on Airbreathing Engines (17th ISABE)*. Munich, Germany, 2005.
22. Li YG, Marini L, Lo Gatto E, et al. Multiple-point adaptive performance simulation tuned to test-bed data. *ALAA Journal of Propulsion and Power*. 2009; 25(3): 635–641. doi:10.2514/1.38823.
23. Blinstrub J, Li YG, Newby M, et al. Application of gas path analysis to compressor diagnosis of an industrial gas turbine using field data. *ASME Turbo Expo 2014*. Germany: Dusseldorf, 2014. GT2014-25330.

Appendix

Nomenclature

DH	enthalpy drop (J/kg)
$\vec{E}$	matching error vector
IGV	angle of inlet guide vane (degree)
m	mass flow rate (kg/s)
m_f	fuel flow rate (kg/s)
N	shaft rotational speed (rpm)
N_E	number of matching errors
N_V	number of matching variables

P	total pressure (atm)
PCN	compressor relative shaft speed
T	total temperature (K)
$TETHP$	entry temperature (K) of turbine HP section
$TETLP$	entry temperature (K) of Turbine LP section
$TFHP$	non-dimensional mass flow rate of turbine HP section
$TFLP$	non-dimensional mass flow rate of turbine LP section
$\vec{V}$	matching variable vector
W_{shaft}	shaft power (MW)
Z	parameter indicating compressor operating point
α	load coefficient
θ	ambient temperature ratio
δ	ambient pressure ratio
β	referred relative shaft power

Acronym

$CTTB$	constant temperature turbine burner
$CPTB$	constant pressure turbine burner
DP	design point
HP/LP	high pressure/low pressure
ISA	international standard atmosphere
OPR	overall pressure ratio
PR	pressure ratio
TET	turbine entry temperature (K)

Subscripts

amb	ambient condition
c	compressor
chk	choke
DP	design point
exd	exhaust duct
HP / LP	high-pressure/low-pressure
ic	inter-stage combustor
map	compressor or turbine map
mc	main combustor
ref	reference condition
req	required
$shaft$	engine shaft
sur	surge



DSPACE

<https://dspace.org/>

Off-design performance control and simulation for gas turbine engines with sequential combustors

Li, Yiguang; Liu, Yang

2025-09

Sage

<https://doi.org/10.1177/09576509251327695>

Li Y-G, Liu Y. (2025) Off-design performance control and simulation for gas turbine engines with sequential combustors. Proceedings of the Institution of Mechanical Engineers, Part A: Journal of Power and Energy, Volume 239, Issue 6, September 2025, pp. 917-935