

The evaluation and calibration of pressure mapping system for the measurement of the pressure distribution of agricultural tyres

by Misiewicz, P.A. , Blackburn, K., Richards, T.E.,
Brighton, J.L. and Godwin, R.J.

Copyright, Publisher and Additional Information: This is the author accepted manuscript.
The final published version (version of record) is available online via Elsevier

Please refer to any applicable terms of use of the publisher.

DOI: 10.1016/j.biosystemseng.2014.12.006

Misiewicz, P.A. , Blackburn, K., Richards, T.E., Brighton, J.L. and Godwin, R.J. 2015. The evaluation and calibration of pressure mapping system for the measurement of the pressure distribution of agricultural tyres. *Biosystems Engineering*. 130, 81-91.

The evaluation and calibration of pressure mapping system for the measurement of the pressure distribution of agricultural tyres

P. A. Misiewicz^{a, 1}, K. Blackburn^a, T. E. Richards^a, J. L. Brighton^a and R. J. Godwin^{a, 1}

^aCranfield University, Cranfield, Bedfordshire, MK43 0AL, UK

¹Harper Adams University, Newport, TF10 8NB, UK

Corresponding author: p.misiewicz@iagre.biz; +44 7752 954149

Abstract

The accuracy of a commercial pressure mapping system was evaluated and a number of techniques for the improvement of pressure measurements were developed. These were required in order to use the pressure mapping system in a tyre/surface interaction study which involved determination of the tyre contact pressure distribution on, both, hard and soil surfaces. In the evaluation of the system, the effect of sensor calibration procedures on the accuracy of the system in measuring pressure was investigated. A purpose built pressure calibration chamber was used to calibrate the sensors, which enabled the proprietary built-in calibration system to be evaluated along with a novel calibration procedure employing, both, an individual and multi-point calibration of each sensing element and the rejection of sensing elements that did not conform to the sensitivity of the majority of the sensing elements. These measures reduced the uncertainty in pressure measurements from $\pm 30\%$ to $\pm 4\%$. Further, evaluation of the compliance of the material was also conducted to enable the sensors to be used for interface pressure measurements between two different surface materials other than those used during sensor calibration. As a result, a procedure for normalising the recorded pressure by adjusting the recorded load output to equal the applied load was established. The improvement of the accuracy of the sensors made it possible for the system to be used to determine the pressure distribution resulting from a range of tyres on a hard surface and in the soil profile.

Keywords: pressure mapping system; calibration; contact pressure; soil – tyre interactions.

1 Introduction

Over the last few decades, farm machinery has increased substantially in weight, increasing loads on the soil and exacerbating compaction problems (Horn, Fleige, Peth, & Peng, 2006). As wheel traffic results in soil compaction (Soane and Ouwerkerk, 1994), a better understanding of soil contact pressure and load transfer to soil through agricultural tyres is essential to provide improved solutions to tyre selection. There is, therefore, a need for an accurate tyre contact pressure measurement system. This article reports on the selection and performance enhancement of a commercial pressure mapping system.

Misiewicz (2010) conducted a review of the commercially available pressure mapping systems, where sensor flexibility, size, pressure resolution, ability to upgradeable the system, customisability, reuse, static vs. dynamic application, test-monitoring capability, modularity and cost were considered. The Tekscan system, I-Scan and Conformat versions (Tekscan, Inc. South Boston, Mass., USA), based on piezo-electric pressure sensors, which enable real-time contact area and pressure distribution to be measured across a multi-sensor array over time (Tekscan, not dated a), was selected for this study due to the sensor size and pressure resolution required to measure the pressure distribution below agricultural tyres. The system measures the load applied to each sensing element and records it as the interface pressure between two surfaces. Tekscan sensors contain thin sensing mats built as a multi-sensor array varying in size, shape, spatial resolution and pressure range. The system contains: (a) piezo-electric pressure sensitive mats (called sensors), (b) data acquisition handle (adaptor) that communicates through a USB interface, (c) data acquisition software and (d) a sensor software map. The system has a wide range of pressure measurement applications including the medical, automotive and furniture design industries. The Tekscan system has an 8-bit output, where each individual sensing element (called a sensel) has a resolution of 0.4% of the full scale output. The thin construction of the sensors allows them to be deformed and permits minimally intrusive/invasive surface pressure measurements (Tekscan, not dated b).

Before the sensor is used, it should be calibrated to convert its output into engineering units and the output variations between individual sensing elements of any given sensor minimised by applying a uniform pressure across the entire sensor; this process is called equilibration (Tekscan, 2006). There have been a number of studies investigating aspects of the Tekscan system accuracy in determining contact pressure and area of contact (Drewniak, Crisco, Spenciner, & Fleming, 2007). Sumiya, Suzuki, Kasahara, and Ogata (1998) concluded that

the Tekscan system does not measure the normal pressures accurately enough for a high level of certainty in terms of absolute values, but it does enable relative comparisons of pressure distribution to be made. Problems of pressure drift, repeatability, linearity and hysteresis were evaluated by Ferguson-Pell, Haggisawa, and Bain (2000) and Wilson, Niosi, Zhu, Oxland, and Wilson (2006), who stressed the importance of calibration to minimise the system errors.

A number of studies have evaluated the effect of the calibration procedure on the accuracy of the system. The proprietary software has two built-in calibration functions, (i) one-point linear and (ii) two-point power calibrations, both with an assumption that zero force equals zero output. These calibrations are conducted by applying a known uniform load to the entire previously equilibrated sensor (Tekscan, 2006). Wilson et al. (2006) and Wilson, Apreleva, Eichler, and Harrold (2003) found that measurements made using a linear calibration were more repeatable and accurate than those made with a two-point power calibration, however, studies conducted by Brimacombe, Anglin, Hodgson, and Wilson (2005) contradicted this finding and showed that the power calibration of the sensors gave significantly lower errors of 2.7%, in comparison to 24.4% and 10.5% obtained for two linear calibrations conducted at 20% and 80% of the maximum load, respectively. Further, their study developed user-defined 3-point quadratic and 10-point cubic calibrations, which were found to further reduce the errors associated with the power calibration to 1.5% and 0.6%, respectively. Similar results were found by DeMarco, Rust, and Bachus (2000). These studies, however, conducted the evaluation of sensor entire output without any consideration given to the output of individual sensing elements.

The previous studies evaluating sensor performance point out the importance of the appropriate calibration of the sensors in order to reduce the uncertainties in the results. This study evaluates the proprietary built-in Tekscan calibration and development of a novel polynomial 'per sensel' calibration and its ability to reduce the errors associated with the pressure determination of individual elements. In order to do so, the following methodology was established:

- (i) The design and construction of a novel pressure calibration device,
- (ii) The evaluation of the Tekscan proprietary calibration,
- (iii) The development and evaluation of a calibration procedure for each sensel with 10 predetermined pressures applied over the operating range where the non-

responsive sensels were disregarded; referred in the following as ‘multi-point per sensel calibration with sensel selection’, and

(iv) The correction of the multi-point per sensel calibration with sensel selection.

This was conducted in order to determine an effective method to measure the pressure distribution below pneumatic agricultural tyres on both hard surfaces and within the soil profile (Misiewicz, 2010).

2 The design and construction of a novel pressure calibration chamber

Each Tekscan sensor needs to be equilibrated and calibrated before being used for pressure measurements; five Tekscan sensors were selected for this study, equilibrated and calibrated using a purpose-built pressure calibration chamber. The calibration of the sensors was conducted by two methods; firstly, the sensors were equilibrated and calibrated following the guidelines from Tekscan (Tekscan, 2006). The second method involved the development of a novel calibration procedure where each sensing element was calibrated separately using the multi-point data procedure. An evaluation of the accuracy of the sensors was conducted after the sensors were calibrated and equilibrated.

The following Tekscan sensors, shown in Fig. 1, were selected, as their size, shape and pressure range were the most suitable for the tyre contact pressure study by Misiewicz (2010):

- Conformat system: Model 5330 sensor
 - standard pressure range: 0 - 0.55×10^5 Pa
 - sensor dimensions: 471.4 mm x 471.4 mm
 - number of sensing elements: 1024
- I-Scan system: Model 6300-A and 6300-B sensors
 - standard pressure range: 0 - 3.45×10^5 Pa
 - sensor dimensions: 264.2 mm x 33.5 mm
 - number of sensing elements: 2288
- I-Scan system: Model 9830-A and 9830-B sensors
 - standard pressure range: 0 - 0.7×10^5 Pa
 - sensor dimensions: 188.6 mm x 203.2 mm
 - number of sensing elements: 176

The standard pressure range of each sensor can be increased or decreased by a factor of 10 using the appropriate software scaling function.

In order to provide a fundamental and independent calibration of the Tekscan sensors, a calibration chamber was designed and constructed to allow the application of uniform pneumatic pressure to all sensing elements being simultaneously calibrated (Misiewicz, 2010). The calibration system consisted of a lower and upper plate, as shown in [Figure-Fig. 2](#) and [Figure-Fig. 3](#). A Tekscan sensor was placed on the smooth ground upper surface of the bottom plate and then a diaphragm placed on the sensor followed by the top plate. The two plates were bolted together by 28 M16 set-screws. Pressure was applied inside the device from the top into the plenum chamber and recorded using a digital pressure gauge (range of 0 – 20 x 10⁵ Pa). The system was designed for a maximum safe working pressure of 34.5 x 10⁵ Pa. Air can be used to pressurise the device up to 8 x 10⁵ Pa, whilst oil is recommended for pressures above 8 x 10⁵ Pa. Depending on the pressure range, a flexible rubber or polythene membrane was used as the diaphragm to seal the device whilst allowing a uniform pressure application to the entire sensor. The entire system weighed 0.28 t.

3 Evaluation of the Tekscan proprietary calibration

Following the manufacturer's recommendations to reduce the effect of drift and hysteresis (Tekscan, 2006), each sensor was conditioned by repeatedly applying air pressure five times, before it was calibrated. Sensors were loaded with uniform pressure to values approximately 20% greater than those expected during the studies. For the equilibration and calibration air pressure was applied to the sensor as follows:

- 1) The equilibration was conducted in 10 increments when pressure was increased. Prior to this process a minimum pressure of 0.1 x 10⁵ Pa was applied to the sensor for one minute to establish an equilibrium condition.
- 2) During the calibration process, a scale factor established during the equilibration process was applied by the proprietary software to each sensing element to make the output uniform between sensels. A two-point calibration was performed by applying two different pressures to the sensor (20% and 80% of the expected maximum pressure). The pressures were applied for one second to allow the pressure to stabilise. Using these data a power law interpolation for overall sensor based on zero load and the two known calibration loads was performed.

Based on the proprietary calibration, the mean, maximum and minimum pressures were determined for each sensor and compared to the applied pressures measured by the air pressure gauge, as shown in Table 1. The bias errors of the overall sensel pressures were less than 3.0% for the Conformat 5300, I-Scan 6300-A and 6300-B sensors; the I-Scan 9830-A and 9830-B produced bias errors as high as 12.5%.

~~Figure-Fig.~~ 4 presents a series of histograms of the residual errors obtained when the sensors were pressurised with uniform pressure. Each histogram presents all the errors obtained for the sensels of the sensor tested at the range of applied pressures. Several outliers were found for each sensor, which give evidence of the presence of “erroneous” sensels. The histograms show that the I-Scan 6300-A, 6300-B, 9830-A and 9830-B gave residual errors up to $\pm 30\%$ nearly normally distributed around “0”. The Conformat 5330 was found to have a tendency to record a higher-than-applied pressure with the errors below 10%. This illustrates that the Tekscan sensors calibrated using the proprietary software give acceptable errors of the mean pressure with some sensels giving large variations in the pressure distribution up to 30%.

As shown by Misiewicz (2010), the entire area of Conformat 5330 provided errors below 10%, and 98% of the area gave errors less than 5%. However, the other four sensors were generally associated with larger errors and only 92% – 98% of the sensing area gave errors less than a 10% error, and 64% – 86% of the area had errors less than 5%.

Following calibration and equilibration using the Tekscan calibration procedure experiments involving rolling loaded tyres over the sensors on a hard surface were conducted. The data were collected by the two I-Scan 9830 sensors, which overlapped the tyre centre line by 50 mm. Figure 5 illustrates contact pressure profiles (cross-sections) found below the centre of a smooth (with the tread removed) Trelleborg T421 Twin Implement 600/55-26.5 tyre. The raw outputs collected by the two sensors from the overlapping area, plotted in Fig. 5a, were found to be similar. When the Tekscan proprietary calibration and equilibration were applied to the data, the results were found to differ significantly by up to 26% (Fig. ~~ure~~ 5b). Hence, the results shown in Fig. 5 confirm a requirement for an evaluation of data modification protocols associated with the proprietary calibration and equilibration, and a requirement for an improved calibration protocol.

To understand the raw output (non-calibrated and non-equilibrated) and the functions that are applied to the data by the Tekscan software, the raw data were collected and analysed. As the Tekscan calibration procedure involves establishing one regression curve for an entire sensor, which is an average value for all the sensing elements, it was necessary to verify the raw output data of each individual sensel in order to determine if they had similar characteristics.

In order to do this the sensors were placed in the calibration chamber and air pressure was applied. Both, the raw output data (non-calibrated and non-equilibrated) and equilibrated data recorded, were plotted against the applied pressure, as shown for the I-Scan 9830-A sensor in Fig. 6. The data were plotted using the proprietary convention for calibration, to enable the pressure to be readily determined from the Tekscan output in the form of the equations given. Figure 6 shows how the Tekscan equilibration function modifies the results. Plotting the data has verified that the output characteristic varied between the sensels, however, the equilibration procedure was found to account for the different calibration characteristics to a great extent. Best-fit power functions were established to visualise the differences in the sensor performance. After the equilibration was applied to the raw output, the maximum variation was found to decrease from 130% to 6%. This agrees with findings of Maurer et al. (2003), who proved that sensor equilibration, which accounts for variations between the individual sensing elements of a sensor, is effective in reducing inter-cell variations.

The evaluation of the raw data showed the variations between the individual sensing elements of a sensor and the importance of equilibration in reducing these variations. This confirmed a need for a multi-point calibration of all the sensors and a separate consideration of each sensing element during the calibration to account for the equilibration of sensors.

4 The development and evaluation of the multi-point per sensel calibration with sensel selection

The second method of calibrating the sensors involved directly recording the raw values available from the Tekscan system when applying a number of air pressures to the sensels in increasing increments. This was conducted in order to establish a multi-point calibration for each individual sensing element and to locate the sensors giving no output or values that were in excess of the expected range.

236 Before calibrating the sensors, they were conditioned by repeatedly (x5) applying a uniform
237 pressure to values approximately 20% greater than those expected during the tests. Then the
238 multi-point calibration was conducted, this involved an application of air pressure across the
239 sensor in 10 increasing increments from 10% to 100% of the maximum pressure expected for
240 each sensor. Each pressure was applied for one second and the raw data recorded and
241 processed in order to establish linear, power, second, third and fourth order polynomial
242 relationships. They were then used for the evaluation of the multi-point per sensel
243 calibration. The identification of erroneous and non-responsive sensels was required in order
244 to eliminate them before the calibration constants were applied. The de-selection was based
245 on the following criteria:

- 246 • non-responsive sensels: the sensels giving zero output when loaded,
- 247 • erroneous sensels: visual selection of outliers.

248
249 The data obtained for the 9830-A sensor were selected for evaluation of the multi-point per
250 sensel calibration, as this sensor was the most appropriate for the experimental work of
251 Misiewicz (2010). The residual errors were plotted as histograms for each type of regression
252 curve and are shown in Fig. 7. The results showed that the design of the multi-point per
253 sensel calibration significantly improved the accuracy of the pressure measurements by
254 reducing the bias errors below 1%. The residual errors were found to be below 7% for the
255 linear calibration, below 5% for the 2nd order polynomial calibration and below 4% for the 3rd
256 and 4th order polynomials. The power function was found to have the least effect in reducing
257 the errors, as the residuals were found to vary from -10% to +20%. Therefore, the findings
258 confirmed that the polynomial functions give the closest fit to the data and improve the
259 accuracy of the system.

260
261 As shown by Misiewicz (2010), the polynomial regression curves gave the best accuracy of
262 the data for the 9830-A sensor with the 4th order polynomial providing residual errors below
263 3% for all sensing elements of the sensor and 88% of the elements giving errors below 1%.
264 In the case of the linear regression, 99% of the sensor area provided errors below 5% and
265 only 51% was associated with errors less than 1%. The power function provided the greatest
266 residual errors, with 71% of the area having errors less than 3% and only 32% of the area had
267 errors less than 1%.

268

In order to further check the accuracy of the multi-point calibration, sets of raw data were obtained by loading the 9830-A sensor with air pressure in the calibration chamber with a previously established multi-point calibration applied to the data. The statistical errors of individual sensing elements were calculated and presented in Fig. 8. Generally, the results were found to slightly underestimate the pressures and the highest statistical errors were found again for the power function, which varied from -10% to $+3\%$. For the linear relationships the errors varied from -7% and $+3\%$. For the 2nd, 3rd and 4th order polynomials the errors were the smallest, varying between -3% and $+2\%$.

The polynomial models give the largest amount of sensing area of the 9830- sensor with small errors; for the 2nd and 3rd order polynomial almost 100% of the sensor area was associated with statistical errors lower than 3% and 60% of the area had errors lower than 1%. The 4th order polynomial function gave slightly improved results as 100% and 67% of the sensing area had statistical errors lower than 3% and 1%, respectively, while for the linear and power functions only 32% and 30% of the area gave errors smaller than 1%, and 80% and 60% gave errors smaller than 3% (Misiewicz, 2010).

The evaluation of the performance of sensors calibrated using the multi-point per sensel calibration with sensel selection was found to improve the accuracy of the results (below $\pm 4\%$), although there were still some residual variations but they were lower than the variations obtained following the proprietary recommended calibration (up to $\pm 30\%$).

5 The correction of the multi-point per sensel calibration with sensel selection

Tekscan sensors have a varied output that depends on the materials used to apply the pressure to the sensor (Tekscan, 2006). The sensors consist of active and non-active areas and the load applied to the active area of each sensel is measured. An assumption made regarding the system is that the same load is applied to the non-active area and the system determines the pressure as the total load over the sensel area. Hence, the flexibility of the material that is in contact with the sensor plays an important role in pressure transfer. It can be assumed that for the highest levels of accuracy, Tekscan sensors should be calibrated with exactly the same interface material as the one used during testing. Unfortunately this is not always possible. In this study, during the calibration, a sensor was placed on the smooth ground surface of a steel plate; a flexible rubber or polythene diaphragm was then placed over the sensor. Air pressure was uniformly applied to the diaphragm. In the tyre contact pressure study of

Misiewicz (2010), both, the hard surface and soil experiments, involved a smooth aluminium plate loaded by a pneumatic tyre and Tekscan sensor placed at the interface either directly or through the soil. Materials with similar characteristics were used in both the calibration and experiments. The rubber and polythene membrane, used in the calibration process, were expected to distribute the pressure in a manner similar to a pneumatic tyre. This was evaluated by comparing the total load applied to the tested tyres and the total load recorded by Tekscan sensors. In case of a poor agreement, a correction factor would need to be developed to account for the compliance of different interface materials and to enable the system to provide pressure measurements between different surface interfaces.

In order to evaluate the requirement for a correction factor, two sets of experiments were conducted. These were as follows:

a. A comparison of the calibration and test environments in a small scale controlled study

This was conducted using the I-Scan 9830 sensors as they were selected, as being those that might produce the greatest discrepancy due to a relatively low spatial resolution of sensels (active area of each sensel: 6.3 mm x 3.8 mm). Initially a multi-point per sensel calibration with the de-selection of faulty sensels was conducted, which was based on the data obtained when loading the sensors in the pressure calibration chamber. The following experiments were then conducted:

- The sensors were loaded with a number of uniform pressures in the pressure calibration chamber (with a polythene diaphragm).
- In order to simulate the hard surface tyre loading environment, the sensors were covered with a polythene membrane and a number of individual sensing elements were randomly selected (excluding any faulty sensels) to which a range of (0 – 500 g) laboratory weights were individually applied through a 2 mm thick square rubber pad of the size of the sensor active area (Fig. 9, left and middle).
- To simulate the soil conditions, the small rubber pad was replaced with sandy loam soil confined in a 2 mm thick larger rubber pad with a central square of the same dimensions as the active area of the sensel removed. Then a range of (0 – 500 g) laboratory weights was applied to the soil placed on the selected sensels (Fig. 9, right).

The effect of the loads applied to the sensels using the three different media (polythene diaphragm, rubber pad and soil) were recorded and compared, as shown in Fig. 10 and Fig. 11. The figures present data obtained for one random sensing element, as other randomly selected sensels showed similar relationships. The tests conducted in the pressure calibration chamber, using polythene diaphragm, provided data recorded by Tekscan that agree with the applied values (Fig. 10), which confirms that the data obtained when loading the sensor in the pressure calibration chamber agree with the previous calibration conducted using the same device. The relationships between the applied and recorded load, shown in Fig. 11, were found to be linear, however, the data recorded by Tekscan, when the loads were applied through the rubber pad and soil, were found to be lower than the applied load. The slopes of the relationships between the applied and measured load were found to be 0.534 and 0.567 for the rubber pad and soil block, respectively. The dissimilarity is related to differences in interface material used and proved a requirement for a correction factor to be used for contact pressure tests if they were conducted using the I-Scan 9830 sensors.

b. A comparison of the load applied to tyres and recorded by the Tekscan system

In order to check similarity of the compliance factor during the calibration and experiments, a comparison of the weight computed from the Tekscan vertical pressure distribution and the total weight applied to a tyre, obtained by Misiewicz (2010), for the two types of Tekscan sensors was conducted.

i. I-Scan 9830 sensors

~~Figure-Fig.~~ Fig. 12 presents relationships of the applied and recorded load for the tyre tested on, both, the hard surface and the soil using the I-Scan 9830 sensors. The recorded loads were less than the applied loads. The slope of the relationship between the applied and recorded load was found to be 0.639 and 0.553 on hard surface and in the soil, respectively, which was similar to the results obtained in the small scale controlled study.

ii. I-Scan 6300 sensors

The I-San 6300 sensors have a higher spatial resolution (active area of each sensel: 3.2 mm x 2.0 mm) than the I-Scan 9830 sensors. The comparison of the loads applied to the tyres and measured by Tekscan, when testing agricultural tyres using the 6300 sensors, agreed to within $\pm 10\%$ of the overall slope of the relationship of 0.95, as illustrated in Fig. 13.

The comparison of the load applied to tyres and measured by Tekscan sensors showed that there is a difference between the applied loads and recorded values obtained for the I-Scan 9830 sensors. This difference was not found to be significant for the 6300 sensor, which has a higher spatial resolution. Therefore, this discrepancy found for the 9830 sensors was assumed to be caused by the fact that different loading materials were used for the calibration and pressure measurements. When the sensors are pressurised with air during the calibration, the pressure is uniform as the air follows the shape of Tekscan sensors. However, soil and rubber are less deformable and follow the shape of the sensors less well. As the recorded loads were considerably lower than the loads applied, it indicates that a large part of the load applied concentrated on the non-active areas of the sensors.

In order to correct the performance of Tekscan sensors in determining the contact pressure between materials different to those used in sensor calibration, all individual contact pressure data points obtained using the sensors should be increased by a correction factor calculated as applied load/recorded load for each test. This adjustment will lead to an agreement between the Tekscan recorded load and the load applied to the sensor.

Finally, the performance of Tekscan sensors in contact pressure measurements below agricultural tyres was evaluated by using the sensors for the contact pressure determination below a selection of tyres. [Figure-Fig. 14](#) presents the contact pressure profile obtained below the treadless T421 Twin Implement 600/55-26.5 tyre after the novel multi-point per sensel calibration was applied to the raw data, previously shown in [Figure-Fig. 5](#). A close agreement between the overlapping sensels in the centre of the tyre contact area was found. This indicates that the development of the new calibration procedure resulted in a significant improvement of the accuracy of the sensors and made it possible to use them to determine the pressure distribution below tyres.

[Figure-Fig. 15](#) shows an example of tyre contact pressure distribution of a Goodyear 11.50/80–15.3 implement tyre on a hard surface at its recommended load of 2.18 ~~tonne~~ at 4.1×10^5 Pa inflation pressure. It was obtained using sensors which were previously calibrated using the multi-point per sensel calibration with sensel selection. It is recommended that this calibration procedure is used to evaluate the accuracy of the other available pressure mapping systems.

6 Conclusions

1. A pressure calibration chamber has shown to be a valuable tool to calibrate the sensors and to evaluate the pressure distribution of the sensors.
2. The pressure mapping sensors calibrated with the proprietary built-in calibration give the majority of bias errors below 3% and the maximum error of 12.5% when measuring the mean pressure, however, individual sensel errors of $\pm 30\%$ were found to be present.
3. When using the multi-point per sensel calibration with sensel selection the bias errors have been reduced below 1% with both residual and statistical errors of $\pm 4\%$ for the polynomial relationships.
4. The sensor equilibration has been found to decrease the maximum variations of Tekscan output from 130% to 6%.
5. Correction to the Tekscan output is required if the sensors are used to measure pressure between various interfaces different from those used in the calibration procedure. The compliance factor can be calculated as a ratio of applied load to load recorded by the sensor.
6. Tyre contact pressure distribution can be more confidently determined using Tekscan sensors after they are calibrated using the multi-point per sensel calibration with sensel selection, a new calibration procedure which improves the accuracy of the sensors.

References

- Brimacombe, J., Anglin C., Hodgson A., & Wilson D. (2005). Validation of calibration techniques for Tekscan pressure sensors. Proceedings of the 20th Congress of the International Society of Biomechanics, Cleveland, OH, 31 July – 5 August 2005.
- DeMarco, A.L., Rust, D.A., & Bachus, K.N. (2000). Measuring contact pressure and contact area in orthopedic applications: Fuji Film vs. Tekscan. 46th Annual Meeting of Orthopedic Research Society, Orlando, Florida, 12 – 15 March 2000.
- Drewniak, E.I., Crisco, J.J., Spenciner, D.B., & Fleming, B.C. (2007). Accuracy of circular contact area measurements with thin-film pressure sensors. *Journal of Biomechanics*, 40, 2569 – 2572.
- Ferguson-Pell, M., Hagsisawa, S., & Bain, D. (2000). Evaluation of a Sensor for Low Interface Pressure Applications. *Medical Engineering & Physics*, 22, no. 9, 657 – 663.
- Horn, R., Fleige, H., Peth, S., & Peng, X. (2006). Soil management for sustainability, Advances in GeoEcology. The 17th Triennial International Soil Tillage Research Conference, CATENA VERLAG GMBH, Kiel, Germany, 28 August – 3 September 2006.

440 Maurer, J.R., Ronsky, J., Loitz-Ramage, B., Andersen, M., Zernicke, R., & Harder, J. (2003).
 441 Prosthetic socket interface pressures: Customized calibration technique for the TEKSCAN F-
 442 socket system. Summer Bioengineering Conference, Florida, 25 – 29 June 2003.

443 Misiewicz, P.A. (2010). The evaluation of the soil pressure distribution and carcass stiffness
 444 resulting from pneumatic agricultural tyres, PhD Thesis, Cranfield University.

445 Soane, B.D., & Ouwerkerk, C. (1994). Soil compaction problems in word agriculture. In B.
 446 D. Soane, & C. Ouwerkerk (Eds). *Soil compaction in crop production* (pp. 1-21). The
 447 Netherlands: Elsevier Science.

448 Sumiya, T., Suzuki, Y., Kasahara, T., & Ogata, H. (1998). Sensing stability and dynamic
 449 response of the F-scan in-shoe sensing system: A technical note. *Journal of Rehab. Res.*
 450 *Devel.*, 35, 192 – 200.

451 Tekscan. (2006). Tekscan I-Scan User Manual, Tactile force and pressure measurements
 452 system, v. 5.8x, published by Tekscan Inc, South Boston, Mass., USA.

453 Tekscan. (not dated a). Tekscan home page, available at: www.tekscan.com (accessed on 15
 454 June 2013).

455 Tekscan (not dated b). Tekscan technology, available at: [http://www.tekscan.com/tekscan-](http://www.tekscan.com/tekscan-technology)
 456 [technology](http://www.tekscan.com/tekscan-technology) (accessed on 1 April 2014).

457 Wilson, D.C., Niosi, C.A., Zhu, Q.A., Oxland T.R., & Wilson, D.R. (2006). Accuracy and
 458 repeatability of a new method for measuring facet loads in the lumbar spine. *Journal of*
 459 *Biomechanics*, 39, 348 – 353.

460 Wilson, D.R., Apreleva, M.V., Eichler, M.J., & Harrold, F.R. (2003). Accuracy and
 461 repeatability of a pressure measurement system in the patellofemoral joint. *Journal of*
 462 *Biomechanics*, 36, 1909 – 1915.

463

464
465 **Figures:**
466 Fig. 1 – Tekscan pressure mapping sensors (from left: Conformat model 5330 sensor, I-Scan
467 model 6300 sensors, I-Scan model 9830 sensors)
468 Fig. 2 – Pressure calibration chamber
469 Fig. 3 – Cross section of the pressure calibration chamber showing the individual components
470 Fig. 4 – Residual error histograms for the 5 Tekscan sensors calibrated using the Tekscan
471 proprietary calibration (please note vertical scales are different between the five sub-figures)
472 Fig. 5 – Cross sectional profiles of tyre contact pressure obtained below a smooth Trelleborg
473 T421 Twin Implement 600/55-26.5 tyre using I-Scan 9830 sensors; a: non-calibrated and
474 non-equilibrated data; b: data calibrated and equilibrated following Tekscan procedure.
475 Dashed ovals indicate the results obtained by overlapping sensels
476 Fig. 6 – Pressure applied vs. output for each sensing element of the I-Scan 9830-A sensor
477 (top: non-calibrated and non-equilibrated data, bottom: non-calibrated but equilibrated data)
478 Fig. 7 – Residual errors for the I-Scan 9830-A sensor after multi-point per sensel calibration;
479 a: linear, b: power, c: 2nd, d: 3rd and e: 4th order polynomial (please note horizontal and
480 vertical scales are different between the five sub-figures)
481 Fig. 8 – Statistical errors for I-Scan 9830-A sensor after the multi-point per sensel calibration;
482 a: linear, b: power, c: 2nd, d: 3rd and e: 4th order polynomial (please note horizontal and
483 vertical scales are different between the five sub-figures)
484 Fig. 9 – Small scale controlled study on the I-Scan 9830 sensors (left and middle: rubber pad
485 tests, right: soil test)
486 Fig. 10 – Measured vs. applied load for I-Scan 9830-A sensor loaded in the pressure
487 calibration chamber using a polythene diaphragm
488 Fig. 11 – Measured vs. applied load for I-Scan 9830-A sensor; left: load applied through a
489 rubber pad, right: load applied through soil (1:1 line dashed)
490 Fig. 12 – Measured vs. applied load for I-Scan 9830 sensors when loaded by the T421 Twin
491 Implement 600/55-26.5 tyre; left: hard surface, right: soil (1:1 line dashed)
492 Fig. 13 – Measured vs. applied load for I-Scan 6300 sensor when loaded by an 11.50/80–15.3
493 implement tyre on the hard surface (1:1 line dashed)
494 Fig. 14 – Cross sectional profile of tyre contact pressure below the treadless T421 Twin
495 Implement 600/55-26.5 tyre obtained using I-Scan 9830 sensors; data calibrated and
496 equilibrated according to the multi-point per sensel calibration. Dashed ovals indicate the
497 results obtained by overlapping sensels

498 Fig. 15 – A Goodyear 11.50/80–15.3 implement tyre at 2.18 ~~tonne~~ load and 4.1×10^5 Pa
499 inflation pressure; left: tyre tread pattern; right: tyre contact pressure distribution (10^5 Pa)
500 obtained using the multi-point per sensel calibration with sensel selection (direction of travel:
501 from right to left)
502
503

504
505 **Table:**
506 Table 1 – Pressure and bias error results based on the Tekscan proprietary calibration
507
508

509

510

511

512

513

514


515



Fig. 1

Tekscan pressure mapping sensors (from left: Conformat model 5330 sensor, I-Scan model 6300 sensors, I-Scan model 9830 sensors)

516



517

518 Fig. 2

519 Pressure calibration chamber

520




Fig. 3

Cross section of the pressure calibration chamber showing the individual components





Fig. 4

Residual error histograms for the 5 Tekscan sensors calibrated using the Tekscan proprietary calibration (please note vertical scales are different between the five sub-figures)

549



550

551 Fig. 5

552 Cross sectional profiles of tyre contact pressure obtained below a smooth Trelleborg T421

553 Twin Implement 600/55-26.5 tyre using I-Scan 9830 sensors; a: non-calibrated and non-


554 equilibrated data; b: data calibrated and equilibrated following Tekscan procedure. Dashed

555 ovals indicate the results obtained by overlapping sensels


556

557

558



559



560

561 Fig. 6

562 Pressure applied vs. output for each sensing element of the I-Scan 9830-A sensor (top: non-

563 calibrated and non-equilibrated data, bottom: non-calibrated but equilibrated data)

564





Fig. 7

Residual errors for the I-Scan 9830-A sensor after multi-point per sensel calibration; a: linear, b: power, c: 2nd, d: 3rd and e: 4th order polynomial (please note horizontal and vertical scales are different between the five sub-figures)

575

576

577



578

579 Fig. 8

580 Statistical errors for I-Scan 9830-A sensor after the multi-point per sensel calibration; a:

581 linear, b: power, c: 2nd, d: 3rd and e: 4th order polynomial (please note horizontal and vertical

582 scales are different between the five sub-figuresfigureFig.s)

583

584

585

586

587

588

589

590

591





Fig. 9

Small scale controlled study on the I-Scan 9830 sensors (left and middle: rubber pad tests, right: soil test)

592



593

594 Fig. 10


595 Measured vs. applied load for I-Scan 9830-A sensor loaded in the pressure calibration

596 chamber using a polythene diaphragm

597

598

599



600

601 Fig. 11


602 Measured vs. applied load for I-Scan 9830-A sensor; left: load applied through a rubber pad,

603 right: load applied through soil (1:1 line dashed)

604

605

606



607

608 Fig. 12


609 Measured vs. applied load for I-Scan 9830 sensors when loaded by the T421 Twin Implement

610 600/55-26.5 tyre-; left: hard surface, right: soil (1:1 line dashed)

611

612

|



613

614 Fig. 13


615 Measured vs. applied load for I-Scan 6300 sensor when loaded by an 11.50/80–15.3

616 implement tyre on the hard surface (1:1 line dashed)

617

618

619




620

621 Fig. 14

622 Cross sectional profile of tyre contact pressure below the treadless T421 Twin Implement
623 600/55-26.5 tyre obtained using I-Scan 9830 sensors; data calibrated and equilibrated
624 according to the multi-point per sensel calibration. Dashed ovals indicate the results obtained
625 by overlapping sensels

626

627



628

629 Fig. 15
630 A Goodyear 11.50/80-15.3 implement tyre at 2.18 ~~tonne~~ load and 4.1×10^5 Pa inflation
631 pressure; left: tyre tread pattern; right: tyre contact pressure distribution (10^5 Pa) obtained
632 using the multi-point per sensel calibration with sensel selection (direction of travel: from
633 right to left)

634

635

636

637 Table 1

638 Pressure and bias error results based on the Tekscan proprietary calibration

Sensor	Pressure applied (10 ⁵ Pa)	Tekscan results			Bias error ¹ (%)
		Mean pressure (10 ⁵ Pa)	Maximum pressure (10 ⁵ Pa)	Minimum pressure (10 ⁵ Pa)	
Conformat 5330	0.689	0.669	0.756	0.559	-2.9
	1.386	1.395	1.498	1.282	+ 0.6
	2.101	2.164	2.392	2.015	+ 3.0
	2.759	2.805	3.343	1.903	+ 1.7
I-Scan 6300-A	0.689	0.705	1.231	0.307	+ 2.2
	1.379	1.385	1.988	0.635	+ 0.5
	2.068	2.059	3.019	1.206	- 0.4
	2.758	2.789	3.019	1.822	+ 1.1
I-Scan 6300-B	0.689	0.678	0.916	0.394	- 1.6
	1.379	1.381	1.626	1.157	+ 0.2
	2.068	2.050	2.424	1.804	- 0.9
	2.758	2.730	3.485	2.344	- 1.0
I-Scan 9830-A	0.138	0.132	0.196	0.084	- 4.0
	0.276	0.256	0.298	0.221	- 7.3
	0.414	0.440	0.478	0.407	+ 6.3
	0.552	0.621	0.716	0.600	+ 12.5
I-Scan 9830-B	0.138	0.145	0.233	0.090	+ 5.5
	0.276	0.265	0.303	0.230	- 4.0
	0.414	0.385	0.414	0.354	- 6.8
	0.552	0.557	0.563	0.495	+ 1.0

639

640

¹ Bias error (%) was calculated as 100% × (Mean pressure - Pressure applied)/(Pressure applied).



DSPACE

<https://dspace.org/>

The evaluation and calibration of pressure mapping system for the measurement of the pressure distribution of agricultural tyres

Misiewicz, Paula A.; Blackburn, Kim; Richards, Terence E.; Brighton, James L.; Godwin, Richard

2015-01-06

Elsevier

<https://doi.org/10.1016/j.biosystemseng.2014.12.006>

Misiewicz PA, Blackburn K, Richards TE, et al., (2015) The evaluation and calibration of pressure mapping system for the measurement of the pressure distribution of agricultural tyres. Biosystems Engineering, Volume 130, February 2015, pp. 81-91